



2119

75
आज़ादी का
अमृत महोत्सव

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/GH//2025/ 94

Dated: 19/02/2025

To,

The Joint Commissioner of Police,
Licensing Unit, 1st floor, Police Station,
Defence Colony, New Delhi.
addlcp.lic-dl@nic.in

Sub: - Inspection report in respect of Hare Rama Guest House, locate at T-416, T-298
Main Bazar, Paharganj, New Delhi- 110055.

Sir,

Please refer to your online application letter No. 2025012501019 dated 27/01/2025, on the subject cited above. In this connection, it is to inform you that the said building was re-inspected by the officer concerned of this department on 11/02/2025 in presence of Mr. Abhishek Aggarwal to check the shortcomings already issued by this department vide letter no. F6/DFS/MS/GH/2025/SZ/11 dated 06/01/2025.

However the Status of the Shortcomings is as under.

S. no.	Shortcomings	Status
1.	Portable fire extinguishers provided found unrefilled and corroded.	Rectified
2.	First Aid Hose Reels provided found non functional.	Not Rectified
3.	MOEFA provided found non functional.	Not Rectified
4.	Terrace fire pump found non functional and rusted.	Not Rectified
5.	Overhead captive water storage for fire fighting tapped for other use/purpose.	Not Rectified

In view of above shortcomings the application for renewal of fire safety certificate is not considered at this stage & rejected. The occupancy of the building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the owner/occupier. The statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully,

(Atul Garg)
Director

18/2/25

Copy To: -

1. The Dy. Health Officer, Karol Bagh Zone, Anand Parbat, New Delhi.
2. The Owner/Occupier M/s Hare Rama Guest House located at T-416, T-298 Main Bazar, Paharganj, New Delhi- 110055.