



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/EH/2025/ 157

Dated: 07/04/2025

To,

The Joint Commissioner of Police,
Licensing Unit, 1st floor, Police Station,
Defence Colony, New Delhi.
adlcp.lic-dl@nic.in

Sub: Inspection report in r/o Hare Rama Guest House, locate at T-416, T-298 Main Bazar, Paharganj, New Delhi- 110055.

Sir,

Please refer to your online application letter No. 2025030903122 dated 09/03/2025, on the subject cited above. In this connection, it is to inform you that this department has already issued shortcoming vide letter No. F6/DFS/MS/GH/2025/94 dated 19/02/2025 & F6/DFS/MS/GH/2025/SZ/11 dated 06/01/2025 (Copy enclosed), is still not complied.

In view of above, the application for issuance of Fire Safety Certificate is not considered at this stage & rejected. The licensing issuing authority/statutory authority is requested not to allow the premises to be operational unless a valid fire safety certificate is issued.

Yours Faithfully,

(Atul Garg)
Director

Copy To:-

1. The Dy. Health Officer, Karol Bagh Zone, Anand Parbat, New Delhi.
2. The Owner/Occupier M/s Hare Rama Guest House located at T-416, T-298 Main Bazar, Paharganj, New Delhi- 110055



2/11/25
Aditya Mahotsav

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/GH/2025/SZ/ 11

Dated: 06/01/2025

To

The Joint Commissioner of Police (Lic.),
First Floor, Police Station Defence Colony.
Andrews Ganj, New Delhi-110049

Sub: Regarding Renewal of Fire Safety Certificate in r/o Hare Rama Guest House located at T-416 & T-298, Main Bazar, Pahar Ganj, New Delhi.

Sir,

Please refer to the online ID No. 2024122018227 dated 20/12/2024, on the subject cited above. In this connection, it is to inform you that the said premise was visited by the officer concerned of this department on 30/12/2024 in the presence of Mr. Galib Reza (Rec. Manager). During the inspection, the shortcomings observed are as below.

1. Portable fire extinguishers provided found unrefilled and corroded.
2. First-aid hose-reel provided found non-functional.
3. MOEFA provided found non-functional.
4. Terrace fire pump found non-functional and rusted.
5. Overhead captive water storage for fire-fighting tapped for other use/purpose.

In view of the above, the application for renewal of fire safety certificate is rejected. The occupancy of the premise/building in the absence of requisite fire safety arrangement shall be at the risk and responsibility of owner/occupier. The licensing/statutory authority may take suitable and necessary action as deemed fit.

Yours faithfully,

(ANUL GARG)
DIRECTOR

T. No. 011-23414000

Copy to: -

1. Ms. Shalini Aggarwal M/s Hare Ramu Guest House located at T-416 & T-298, Main Bazar, Pahar Ganj, New Delhi-110055