

c/142

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F.6/DFS/MS/NDZ/2025/ 354

Dated: 18.08.2025

To,

The Manager,
M/s Hare Rama Guest House,
T-146, T-298, Main Bazar, Pahar Ganj,
New Delhi.

Sub: Application for renewal of fire safety certificate in respect of M/s Hare Rama Guest House, T-146, T-298, Main Bazar, Pahar Ganj, New Delhi.

Sir,

This has reference to your online id no. 2025070510970 dated 21.07.2025, on the subject cited above. In this regard, it is to inform you that site was visited by officer concerned of this department on dated 08.08.2025 in presence of Mr. Galib and observed that point no. 1,2 & 4 in the shortcomings issued earlier vide letter no. F6/DFS/MS/GH/NDZ/311 dated 01/07/2025 (copy enclosed) is still not complied.

In view of above, the case is rejected and Fire Safety Certificate cannot be renewed at this stage. Therefore, you are requested to comply all the shortcomings for further consideration in the matter.

Encl: As above.

Yours faithfully,


18/08/2025
(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to :

1. The Commissioner MCD, Civic Center, New Delhi.

c/140 : c/130

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/GH/NDZ/311

Dated: 01.07/2025

To,
The Manager,
M/s Hare Rama Guest House,
T-146, T-298, Main Bazar, Pahar Ganj,
New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/s Hare Rama Guest House, T-146, T-298, Main Bazar, Pahar Ganj, New Delhi.

Sir,

This has reference to on line ID No. 2025052609090 dated 19.06.2025, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 25/06/25 in the presence of Mr. Galib Manager and following shortcomings were observed:

1. Smoke management system is found nonfunctional.
2. Co detectors are not provided in some rooms and some are found nonfunctional.
3. MCP & PA found nonfunctional.
4. Further, 08 nos of rooms are shown in the building plans and same are operating whereas only 03 rooms are filled in application form, accordingly clarification is required to be submitted to use of extra rooms.

In view of above e, the case is rejected and Fire Safety Certificate (FSC) cannot be renewed at this stage due to above shortcomings. Therefore, you are requested to rectify/ clarify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,

(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:

1. The Commissioner MCD, Civic Center, New Delhi.