

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001

Dated: 23/05/2025

No. F6/DFS/MS/WZ/GH/2025/252

To,

The Joint Commissioner of Police,
Licensing Unit, 1st floor, Police Station,
Defence Colony, New Delhi.
addlcp.lic-dl@nic.in

Sub: Inspection report in r/o Hare Rama Guest House, locate at T-416, T-298 Main Bazar, Paharganj, New Delhi- 110055.

Sir,

Please refer to your online application letter No. 2025050808109 dated 09/05/2025, on the subject cited above. In this connection, it is to inform you that this department has already issued shortcoming vide letter No. F6/DFS/MS/GH/2025/94 dated 19/02/2025, F6/DFS/MS/GH/2025/SZ/11 dated 06/01/2025 & F6/DFS/MS/WZ/EH/2025/157 dated 07/04/2025, is still not complied.

In view of above, the application for renewal of Fire Safety Certificate is not considered at this stage & rejected. The licensing issuing authority/statutory authority is requested not to allow the premises to be operational unless a valid fire safety certificate is issued.

Yours Faithfully,

(Atul Garg)
Director

Copy To:-

1. The Dy. Health Officer, Karol Bagh Zone, Anand Parbat, New Delhi. Online ID No. 2025050808109 dated 09/05/2025.
2. The Owner/Occupier M/s Hare Rama Guest House located at T-416, T-298 Main Bazar, Paharganj, New Delhi- 110055.



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/EH/2025/ 157

Dated: 07/04/2025

To,

The Joint Commissioner of Police,
Licensing Unit, 1st floor, Police Station,
Defence Colony, New Delhi.
addlcp.lic-dl@nic.in

Sub: Inspection report in r/o Hare Rama Guest House, locate at T-416, T-298 Main Bazar, Paharganj, New Delhi- 110055.

Sir,

Please refer to your online application letter No. 2025030903122 dated 09/03/2025, on the subject cited above. In this connection, it is to inform you that this department has already issued shortcoming vide letter No. F6/DFS/MS/GH/2025/94 dated 19/02/2025 & F6/DFS/MS/GH/2025/SZ/11 dated 06/01/2025 (Copy enclosed), is still not complied.

In view of above, the application for issuance of Fire Safety Certificate is not considered at this stage & rejected. The licensing issuing authority/statutory authority is requested not to allow the premises to be operational unless a valid fire safety certificate is issued.

Yours Faithfully,

(Atul Garg)
Director

Copy To:-

1. The Dy. Health Officer, Karol Bagh Zone, Anand Parbat, New Delhi.
2. The Owner/Occupier M/s Hare Rama Guest House located at T-416, T-298 Main Bazar, Paharganj, New Delhi- 110055

04/4/25



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

Dated: 06/01/2025

No. F.6/DFS/MS/GH/2025/SZ/ 11

To

The Joint Commissioner of Police (Lic.),
First Floor, Police Station Defence Colony,
Andrews Ganj, New Delhi-110049

Sub: Regarding Renewal of Fire Safety Certificate in r/o Hare Rama Guest House located at T-416 & T-298, Main Bazar, Pahar Ganj, New Delhi.

Sir,

Please refer to the online ID No. 2024122018227 dated 20/12/2024, on the subject cited above. In this connection, it is to inform you that the said premise was visited by the officer concerned of this department on 30/12/2024 in the presence of Mr. Galib Reza (Rec. Manager). During the inspection, the shortcomings observed are as below.

1. Portable fire extinguishers provided found unrefilled and corroded.
2. First-aid hose-reel provided found non-functional.
3. MOEFA provided found non-functional.
4. Terrace fire pump found non-functional and rusted.
5. Overhead captive water storage for fire-fighting tapped for other use/purpose.

In view of the above, the application for renewal of fire safety certificate is rejected. The occupancy of the premise/building in the absence of requisite fire safety arrangement shall be at the risk and responsibility of owner/occupier. The licensing/statutory authority may take suitable and necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

T. No. 011-23414000

Copy to: -

1. Ms. Shalini Aggarwal M/s Hare Rama Guest House located at T-416 & T-298, Main Bazar, Pahar Ganj, New Delhi--110055



GOVERNMENT OF DELHI CAPITAL TERRITORY OF DELHI
HEADQUARTERS DELHI FIRE SERVICE, NEW DELHI-110001

Dated: 19/02/2025

No. F6/DFS/MS/GH//2025/ 94

To,

The Joint Commissioner of Police,
Licensing Unit, 1st floor, Police Station,
Defence Colony, New Delhi.
addlep.lic-dl@nic.in

**Sub: - Inspection report in respect of Hare Rama Guest House, locate at T-416, T-298
Main Bazar, Paharganj, New Delhi- 110055.**

Sir,

Please refer to your online application letter No. 2025012501019 dated 27/01/2025, on the subject cited above. In this connection, it is to inform you that the said building was re-inspected by the officer concerned of this department on 11/02/2025 in presence of Mr. Abhishek Aggarwal to check the shortcomings already issued by this department vide letter no. F6/DFS/MS/GH/2025/SZ/11 dated 06/01/2025.

However the Status of the Shortcomings is as under.

S. no.	Shortcomings	Status
1.	Portable fire extinguishers provided found unrefilled and corroded.	Rectified
2.	First Aid Hose Reels provided found non functional.	Not Rectified
3.	MOEFA provided found non functional.	Not Rectified
4.	Terrace fire pump found non functional and rusted.	Not Rectified
5.	Overhead captive water storage for fire fighting tapped for other use/purpose.	Not Rectified

In view of above shortcomings the application for renewal of fire safety certificate is not considered at this stage & rejected. The occupancy of the building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the owner/occupier. The statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully,

(Atul Garg)
Director

Copy To: -

1. The Dy. Health Officer, Karol Bagh Zone, Anand Parbat, New Delhi.
2. The Owner/Occupier M/s Hare Rama Guest House located at T-416, T-298 Main Bazar, Paharganj, New Delhi- 110055.

18/2/25