

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/8
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/GH/2025/SZ/339

Dated: 04 /08/2025

To,

The Commissioner,
MCD Civic Center,
Jawahar Lal Nehru Marg,
New Delhi - 110002.


Subject: - Regarding issuance of Fire Safety Certificate in r/o M/s Harsha International Guest House at AK-22, Arakashan Road, Pahar Ganj, New Delhi-110055.

Sir,

Please refer to your MCD Portal application No. 2025071211306 dated 13/07/2025 on the subject cited above. In this connection, it is to inform you that the site was visited by officer concerned of this department on 23/07/2025 in the presence of Mr. Rishi Chauhan (Manager) and observed that the shortcoming is still not complied with as issued by this department vide letter no. F6/DFS/MS/NDZ/2022/GH/448 dated 08/06/2022 (copy overleaf).

In view of above, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier.

Yours faithfully,


VIRENDRA SINGH
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to: -

1. The Manager, Harsha International Guest House, AK-22, Arakashan Road, Pahar Ganj, New Delhi - 110055.

2103 291

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No. F.6/DFS/MS/NDZ/2022/CH/448

Dated: 08/06/2022

To

The Manager,
M/S Harsha International,
AK 22, AK Road, Pahar Ganj,
New Delhi.

Subject:- Online Application ID No.- 2022032404130 dated 24.03.22 in r/o M/S Harsha International at AK 22, AK Road, Pahar Ganj; New Delhi

Sir,

This has a reference to online application ID No.- 2022032404130 dated 24.03.22 & e-mail <amarbansalaic@gmail.com> dated 10.05.2022 on the subject cited above. In this connection, it is to inform you that the site was visited on dated 27.05.22 by the officers concerned of this department and observed following shortcomings.

1. Only one staircase of 1.35 meter is provided against the requirement of 02 staircase of 1.5 meter each.
2. Width of corridor is 1.0 against the requirements of 1.80 meter.
3. Overhead water tank is 2500 liter against the requirements of 5000 liter.
4. Terrace pump of 225 LPM is provided against the requirements of 450 LPM.
5. No. of rooms being used in the guest house as per building plans are not matching with the guest room filled in online application. Further, no. of room at fourth floor are not allowed (as mentioned in online application) as per gazette notification dated 27.05.2019.

Therefore, you are requested to rectify the above shortcomings and fill the correct information in Performa & resubmit the application for further consideration in the matter.

Yours faithfully,

(Atul Garg)
DIRECTOR
Delhi Fire Officer

Copy to :-
The Jt. Commissioner of Police (Lic),
1st Floor, Defense Colony Police Station, New Delhi.