

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/EH/2025/SZ/362

Dated: 28/10/2025

FIRE SAFETY CERTIFICATE

Certified that the **Haldiram (A unit of Haldiram Ethnic Foods Pvt. Ltd.), Shop No. C9/14, Krishna Nagar, Shahdara, Delhi - 51**, comprised of Basement (Storage), Ground, 1st, 2nd & 3rd floor but restaurant is running only in Ground (restaurant), 1st (restaurant) with Basement (Storage) owned / occupied by Haldiram Ethnic Foods Pvt. Ltd., was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/EH/2022/NDZ/198 dated 06/07/2022. The premise was re-inspected by the officer concerned of this department on 12/10/2025 in the presence of Mr. Atul Singh (Manager) and found that the said building(restaurant)/premises is fit for occupancy class "**Group D(Assembly Building)**" with effect from 28/10/2025 with valid upto 31/03/2028 in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 28/10/2025 at New Delhi by


(Dr. S. K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service
o/c

Copy to: -

- ✓ The Commissioner, Municipal Corporation of Delhi, Dr. SPM Civic Center, Minto Road, New Delhi-110002 (w.r.t. online application No. 2025100113895 dated 01/10/2025).
- Sh. Ashish Agarwal, Haldiram (A unit of Haldiram Ethnic Foods Pvt. Ltd.), Shop No. C9/14, Krishna Nagar, Shahdara, Delhi - 51.

Conditions for the validity of Fire Safety Certificate:

- All the means of escape/entry/exit shall be kept free from any obstruction.
- All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
- All the staff members must know the correct method of operation of fire-fighting system.
- Basement shall be used strictly in accordance with the BBL.
- This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
- The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
- The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, prior to its expiry.
- Fire Safety Certificate is valid for Ground (restaurant), 1st (restaurant) with Basement (Storage) only

INSPECTION REPORT

1.	Name & address of the building	Haldiram (A unit of Haldiram Ethnic Foods Pvt. Ltd.), Shop No. C9/14, Krishna Nagar, Shahdara, Delhi - 51		
2.	Type of Occupancy	Assembly (Group-D)		
3.	Building Comprised of	Restaurant running on Ground and First floors with basement (storage)		
4.	Type of Case	Renewal		
5.	Details of previous NOC	F6/DFS/MS/EH/2022/NDZ/198 dated 06/07/2022		
6.	Fire Safety directives letter No	Nil		
7.	Date of inspection	12/10/2025		
8.	Name of the Inspecting Officers	Kaushal Kishore (ADO SJ)		
	Name and designation of officers from the building side	Sh. Atul Singh (Manager)		
10.	Year of Construction	2011		
11.	Applicant's letter No.	Application No. 2025100113895 dated 01/10/2025		
S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL /NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mtr	On main road	MR
	• Gate width	N/A	On main road	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	01	01	MR
	b. Width of staircases			
	• Upper Floors	1.50m	1.50m	MR
	• Basements	1.50m	1.50m	MR
	c. Protection of exits			
	• Fire check door	Required in basement	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.5m	1.5m	MR
3	Compartmentation.			
	• Fire check door	Required in basement	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided	MR
5	Fire Extinguishers			
	• Total numbers	06 nos.	06Nos	MR

		ISI marked		
6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	01	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A (area less than 200m ²)	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• Size of riser/down-comer	150mm	150mm	MR
	• Number of hydrants per floor	1	1	MR
	• Hose Box	1	1	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access			
	• Terrace level	450LPM	900LPM (Electrical) 900 LPM (Diesel) 180 LPM (Jockey)	MR
	➤ Discharge of pump			
	➤ Head of the pump	40MH	40MH	MR
	➤ Power Supply	Required	Required	MR
	➤ Auto Starting of pump	Required	Required	MR
14	Captive Water Storage for fire-fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	20,000 ltrs	25,000 ltrs	MR
15	Exit Signage.	Required	Provided	MR

n/7

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the substantial compliance of the minimum standard on fire prevention & fire safety measures as required under the rules, issuance of fire safety certificate, **under rule 35 of Delhi Fire Service Rules 2010** is recommended.


 Signature of the Inspecting Officer
 Kaushal Kishore ADO (SJ)

DO(ED)  21/11/25

By. Cfo (NDZ)  21/10/25

Principal Director

By. Cfo to 

By. Cfo (NDZ)  21/10/25

ADG (SS) 

 23/10/25