




GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F6/DFS/MS/WZ/2025/Collage/ 57
To,

Dated: 16/05/2025

Dr. Ajay Kumar,
M/s Health and Education Society
Located at 2A & 2B Complex, PSP, Institution, Area,
Madhuban Chowk, Rohini,
Delhi-110085.

Sub: Renewal of FSC in r/o M/s Health and Education Society at 2A & 2B Complex, PSP, Institution, Area, Madhuban Chowk, Rohini Delhi-110085.

Sir,

Kindly reference to online e-mail dated 24.02.2025, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 22.04.2025, in presence of **Dr. Bahugana** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. 6mtr road all around the building found non-accessible by fire tender due to some additional/alternation.
2. Smoke management system in upper floor found blocked & basement found removed.
3. Hydrant system in building was inaccessible at some places.
4. FCD found removed in basement.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours faithfully

(Atul Garg)
DIRECTOR

Ph; 011-23414000

OK
On