GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/NDZ/364

Dated:-..0.7. 198./2025

To.

Authorized Signatory, Hemkunt House, at Plot No. 06, Rajendra Place, New Delhi-110008.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Hemkunt House, at Plot No. 06, Rajendra Place, New Delhi- 110008.

Sir,

This has reference to your letter no. <a href="mailto:<me">hemkuntassociation@gmail.com dated 30.06.2025, on the subject cited above. In this regard, it is to inform you that the site was inspected by Officers concerned of this department along with Sh. Deepak, Chawla, General Secretary on dated 22.07.2025 and following shortcomings are still not complied in the building.

- 1. Fire check door in basement for compartmentation is not provided and alternate staircase serving to basement also found locked/ blocked.
- 2. Temporary offices in basement is constructed which need to be vacated and an undertaking is required to be submitted that basement shall be used as per BBL concerned.
- 3. Smoke exhaust system is still not provided in basement
- 4. Further, trimming of trees is also required to ensure unobstructed access for fire tenders in case of any emergency.

In view of above, Fire Safety Certificate (FSC) cannot be renewed till compliance of all the shortcomings. Therefore, you are requested to rectify all the shortcomings at the earliest for further consideration in the matter. Further, the occupancy of the building/premises in absence of requisite fire safety arrangements shall be at risk and liability of owner/occupier.

Encl: As above.

Yours faithfully,

(Virendra Singh) Chief Fire Officer Delhi Fire Service

Copy to:-

The Commissioner of MCD, Civic Centre, New Delhi.