GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/EH/WZ/2026/564 Dated: 11 /06/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Center, New Delhi – 110002.

Subject: - Regarding Issuance of Fire Safety Certificate in r/o Hesetasse Beverages Pvt. Ltd. located at Building no. 5, North West Avenue, Club Road, Punjabi Bagh, Delhi-110026.

Sir,

This has a reference to MCD application No. 2026052107266 dated 21/05/2026, on the subject cited above. In this connection, this is to inform you that the above-mentioned premises was visited by the officer concerned of this department on dated 01/06/2026 in the presence of Mr. Sidharth to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observation: -

1. Width of door size 1m X 2 is provided against the requirement of 1.5 m X 2.
2. First Aid Hose reel is provided but found not functional.
3. Terrace pump of capacity 450 LPM provided but found not functional.
4. Overhead tank capacity of 3,000 lit. provided against the requirement of 20,000 lit.
5. Exit Signage not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is **rejected.** The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

01/06/26

(S. K. Dua)
Chief Fire Officer
Delhi Fire Service

Copy to :

1. The Owner/Occupier, Hesetasse Beverages Pvt. Ltd. located at Building no. 5, North West Avenue, Club Road, Punjabi Bagh, Delhi-110026.