



No. F6/DFS/MS/School/NDZ/2025/ 797

Dated: 18/06/2025

FIRE SAFETY CERTIFICATE

Certified that the Hillman Public School located at S – 551, School Block, Shakarpur, Delhi – 110092, comprised of basement (Store), ground plus one upper floor owned/occupied by Hillman Public School was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2019NDZ/547 dated 15/03/2019. The School building was re-inspected by the officer concerned of this department on 09/06/2025 in presence of Mrs. Pushpa Badola (Principal) and found that school have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. 262 - 362 dated 17/01/2005 issued by Director of Education and the building premises is fit for occupancy of class Group B “Educational Building” with effect from 18/06/2025 for a period of **three years** in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 18/06/2025 at New Delhi by.

(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to: -

1. The Director of Education (GNCT), Old Secretariat, Delhi - 110054.
2. The Principal, Hillman Public School located at S – 551, School Block, Shakarpur, Delhi – 110092.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. At the time of inspection basement store purpose used only.
7. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & address of the building	Hillman Public School located at S - 551, School Block, Shakarpur, Delhi - 110092.		
2	Building is comprised of	Basement (Store), Ground plus one upper floor.		
3	Type of occupancy	Educational Building		
4	Type of case	Renewal Case		
5	Details of previous FSC	F6/DFS/MS/School/2019NDZ/547 dated 15/03/2019		
6	Fire safety directives letter no.	Circular No. 262 - 362 dated 17/01/2005		
7	Date of inspection	09/06/2025		
8	Name of the inspecting officers	Yashwant Singh Meena, ADO/ Laxmi Nagar		
9	Name of the designation of officer from the building side	Mrs. Pushpa Badola (Principal)		
10	Year of construction	2000		
11	Applicant's letter no.	Outdoor diary no. 2005 dated 22/05/2025		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Circular Requirement	Provided at site	Remarks MR/NMR
1	Access to Building:			
	A Road width	6.0 meters.	6.0 meters.	MR
	B Gate width	N/A	N/A	N/A
	C Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits:			
	A Number of staircases			
	a Upper floor	01 no.	02 nos.	MR
	b Basement	01 no.	01 no.	MR
	B Width of staircases			
	a Upper floor	1.50 meters	1.20 meter & 0.75 meter	MR
	b Basement	1.20 meters	1.20 meters	MR
	C Protection of exits			
	a Fire check door	N/A	N/A	N/A
	b Pressurization	N/A	N/A	N/A
	D No. of continuous staircases to terrace	01 no.	01 no.	MR
	E Width of corridor	1.50 meters	1.50 meters	MR
	F Door size	1.0 meter.	1.0 meter.	MR
3	Compartmentation:			
	A Fire check door	N/A	N/A	N/A
	B Sealing of electrical shafts	N/A	N/A	N/A
	C Fire rating of shaft door	N/A	N/A	N/A
	D Water curtain	N/A	N/A	N/A
	E Fire dampers	N/A	N/A	N/A
4	Smoke Management System:			
	A Basement	N/A	N/A	N/A
	B Upper floor	N/A	N/A	N/A


5.	Fire Extinguisher:				
	A	Total numbers	06 nos.	08 nos.	MR
	B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
	C	ISI marking	ISI Marked	Provided	MR
6	First-Aid-Hose Reel:				
	A	Total numbers of each floor	01 no.	01 no.	MR
	B	Length of hose reel hose	30 mtr.	30 mtr.	MR
	C	Nozzle diameter	05 mm	05 mm	MR
7	Automatic Fire Detection and Alarming System:				
	A	Type of detectors	N/A	N/A	N/A
	B	Location of main panel	N/A	N/A	N/A
	C	Location of repeater panel	N/A	N/A	N/A
	D	Alternate source of power	N/A	N/A	N/A
	E	Hooters	N/A	Provided	MR
8	MOEFA:		N/A	N/A	N/A
9	Public Address System:		N/A	Provided	MR
10	Automatic Sprinkler System:				
	A	Basement	Required	Provided	MR
	B	Upper floor	N/A	N/A	N/A
	C	Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants:				
	A	Size of riser/down-comer	N/A	N/A	N/A
	B	Number of hydrants per floor	N/A	N/A	N/A
	C	Hose box	N/A	N/A	N/A
12	Yard Hydrants:				
	A	Total number of hydrants	N/A	N/A	N/A
	B	Hose box	N/A	N/A	N/A
13	Pumping Arrangements:				
1	Ground level				
	A	Discharge of main pump	N/A	N/A	N/A
	B	Head of main pump	N/A	N/A	N/A
	C	Number of main pumps	N/A	N/A	N/A
	D	Jockey pump out put	N/A	N/A	N/A
	E	Jockey pump head	N/A	N/A	N/A
	F	Standby pump out put	N/A	N/A	N/A
	G	Standby pump head	N/A	N/A	N/A
	H	Auto starting /manual stopping	N/A	N/A	N/A
	I	Pump house access	N/A	N/A	N/A
2	Terrace Level				
	A	Discharge of pump	450 LPM	450 LPM	MR
	B	Head of the pump	40 m	40 m	MR
	C	Power supply	Required	Provided	MR
	D	Auto starting of pump	Required	Provided	MR

14	Captive Water Storage for Fire Fighting:			
	A	Underground tank capacity	N/A	N/A
	B	Draw-off connection	N/A	N/A
	C	Fire service inlet	N/A	N/A
	D	Access to tank	N/A	N/A
	E	Overhead tank capacity	5000 liters	5000 liters
15	Exit Signage:		N/A	N/A
16	Provision of Lifts:			
	A	Pressurization of lift shaft	N/A	N/A
	B	Pressurization of lift lobby	N/A	N/A
	C	Communication in lift car	N/A	N/A
	D	Firemen's grounding switch	N/A	N/A
	E	Lift signage	N/A	N/A
17	Standby Power Supply:		N/A	N/A
18	Refuge Area:			
	A	Total area	N/A	N/A
	B	Location	N/A	N/A
19	Fire Control Room:			
	A	Detector system panel	N/A	N/A
	B	Flow switch panel	N/A	N/A
	C	PA system panel	N/A	N/A
	D	Battery backup	N/A	N/A
	E	Building floor plans	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:		N/A	N/A

Note: - At the time of inspection that the school running ground + 01 floor and basement not in use as per undertaking enclosed.

The fire protection system provided in the school building were tested, checked at random and found functional at the time of inspection.


Keeping in view of the deemed compliance of minimum standards on fire prevention and fire safety measures as required under the Rules the Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/2019NDZ/547 dated 15/03/2019 Renewal under rule 35 (6) of the Delhi Fire Rules 2010 is recommended.



 Signature of the Inspecting Officer
 Name: - Yashwant Singh Meena
 Designation: - ADO/Laxmi Nagar

D.O/EAST


 10/06/2025


 ADO/NDZ


 C.F.O.
 12/06/2025


 Director
 13/06/25