

2/9/25

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F.6/DFS/MS/2025/97/405

Dated 03/10/2025

To,

Authorized Signatory,
M/S Hilson Guest House (A Unit of Manish Gulati and Sons HUF),
E-240, Main by Pass Road, first 60 ft road, Molarband Extn.
Badarpur Delhi.

Sub:-Regarding renewal of FSC in r/o M/S Hilson Guest House (A Unit of Manish Gulati and Sons HUF), E-240, Main by pass Road, first 60 ft road, Molarband Extn. Badarpur Delhi.


Sir,

This has reference to id no.2025091213404 dated 12.09.2025, on the subject cited above. In this connection it is to inform that the site was visited by the officers concerned of this department on 24/09/2025 in the presence of Manager and the following shortcomings were observed:-

1. Hose reel and pumps found nonfunctional and nozzle was also found missing at some hose reel and hose reel is also not provided in basement
2. Smoke management system is not provided.
3. MOEFA and detection system found nonfunctional.

In view of above case is rejected with a request to rectify the above shortcomings at the earliest for further consideration in the matter.

Yours faithfully,


(A.K. Malik)
Dy. Chief Fire Officer

✓

Copy to:-

The Commissioner of MCD, Civic Centre, New Delhi.