



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F.6/DFS/MS/BP/2026/32

Dated: 29.01.2026

To,

The Dy. Director (L&I) Bldg.,
DDA Vikas Sadan,
New Delhi.

**Sub: Rejection of online building plans belonging to Him Hit CGHS Ltd. at Plot No. 8,
Sector-22, Dwarka, Phase-I, New Delhi for addition & alteration.**

Sir,

With reference to online file no. DW22/0097/2025 dated 29.11.2025 on the subject cited above; it is informed that the referred online building plans in respect of proposed existing residential blocks of Him Hit CGHS Ltd. at Plot No. 8, Sector-22, Dwarka, Phase-I, New Delhi. were scrutinized under rule 34 of The Delhi Fire Service Rules, 2010 and following shortcomings were observed:-

1. The width of the staircases proposed on the plans is 1.25m each, while the said width is not matching with the actual width as reported after inspection by officer of this department.

In view of the above, the building plans are **rejected** with a request to resubmit plans after rectification of above shortcomings for further consideration.

Yours faithfully,

(M. K. Chattopadhyay)
Dy. Chief Fire Officer
Delhi Fire Service