



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F6/DFS/MS/Audi/ECN/2026/ 131

Dated :06./07./2026

FIRE SAFETY CERTIFICATE

Certified that **Hindi Bhawan Auditorium** located at **11, Vishnu Digambar Marg, New Delhi** comprised of Basement, Ground & 05 Upper Floors was earlier issued Fire Safety Certificate by this department vide letter No. **F6/DFS/MS/2023/NDZ/120** dated **28.02.2023**. Now, the premises was inspected by the officers concerned of this department on **20/05/2026** in the presence of **Sh. Balam Singh, Technician** and found that the said building has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class - **Assembly Occupancy (Group - D) for Auditorium running at Ground, Mezzanine and First Floor Only** with effect from **06/07/2026** for period of Three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued ...**06/07/2026**...at New Delhi by...


6/7/26

(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Chairman, NDMC, Palika Kendra, New Delhi - 110001.
2. The Secretary, Hindi Bhawan Auditorium, 11, Vishnu Digambar Marg, New Delhi - 110001.

Conditions for the validity of Fire Safety Certificate

1. This FSC is valid for Auditorium at Ground, First and Mezzanine floor only.
2. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
3. Any loss of life or property due to nonfunctional fire safety measures shall be at the responsibility of the management.
4. The trained firefighting staff should be available round the clock.
5. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
10. Any flammable material for interior decoration is prohibited.

INSPECTION REPORT

1.	Name & address of the building	Hindi Bhawan Auditorium, 11, Vishnu Digambar Marg, New Delhi.		
2.	Type of occupancy	Assembly Building		
3.	Building comprised of:	Basement, Ground & 05 Upper Floors But Auditorium at Ground, First and Mezzanine Floor only.		
4.	Type of case	Renewal		
5.	Details of previous FSC No.	F6/DFS/MS/2023/NDZ/120 dated 28.02.2023		
6.	Fire safety directives No.-	F6/DFS/MS/93/1616 dated 30.09.1993		
7.	Date of inspection: -	20/05/2026		
8.	Name of the inspecting officer: -	Sh. Manish Kumar, DO(CD) Sh. Bhupender Prakash, ADO(CC)		
9.	Name & designation of officer From the building side: -	Sh. Balam Singh, Technician		
10.	Year of construction: -	1996		
10.	Applicant's letter No: -	DFS Online Portal ID: - 52026030601435 dated 09.03.2026		
S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Existing	Provided at site	Remarks MR/NMF
1.	Access to Building			
	• Road width	9.00 mtr.	12.00 mtr.	MR*
	• Gate width	4.50 mtr.	4.50 mtr.	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper floors	02 nos.	02 nos.	MR
	• Basements	02 nos.	02 nos.	MR
	b. Width of staircase			
	• Upper floors	1.00 & 1.20 mtr.	1.00 & 1.20 mtr.	MR
	• Basements	1.00 & 1.20 mtr.	1.00 & 1.20 mtr.	MR
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	02 nos.	02 nos.	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1.00 mtr.	1.00 mtr.	MR
3.	Compartmentation			
	• Fire check door (in Basement)	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire rating of shaft door	Required	Provided	MR
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided Natural	MR
5.	Fire Extinguishers			
	• Total numbers	24 nos.	30 nos.	MR
	• Types	ABC & CO ₂	ABC, CO ₂ & W.CO ₂	MR
	• ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	• Total number of each floor	03 nos.	01 no. at each floor and 02	MR

			nos. on the Stage	
	• Length of hose reel hose	30 mtr.	30 mtr.	MR
	• Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System.			
	• Type of detectors	Required	Provided	MR
	• Location of main panel	Required	Provided	MR
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Upper floors (Stage)	Required	Provided	MR
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	01 no.	01 no.	MR
	• Hose box per floor	01 no.	01 no.	MR
12.	Yard Hydrants			
	• Total number of hydrants	02 nos.	02 nos.	MR
	• Hose box	02 nos.	02 nos.	MR
13.	Pumping Arrangement			
	Ground level			
	• Discharge of main pump	1800 LPM	Provided	MR
	• Head of main pump	70 mtr	Provided	MR
	• Number of main pumps	02 nos.	Provided	MR
	• Jockey pump out put	220 LPM	Provided	MR
	• Jockey pump head	70 mtr	Provided	MR
	• Stand by pump output	1800 LPM	Provided	MR
	• Stand by pump head	70 mtr.	Provided	MR
	• Auto starting/Manual stopping	Required	Provided	MR
	Terrace level			
	• Discharge of pump	N/A	450 LPM	N/A
	• Head of pump	N/A	40 mtr.	N/A
	• Power supply	N/A	Provided	N/A
	• Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	1,00,000 Ltrs	1,00,000 Ltrs	MR
	• Draw-off connection	Required	Provided	MR
	• Fire service inlet	Required	Provided	MR
	• Access to tank	Required	Provided	MR
	• Overhead tank capacity	20,000 Ltrs	20,000 Ltrs	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A

	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	Required	Provided	MR
	• Fireman's switch	Required	Provided	MR
	• Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area			
	• Total Area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

*PNF - Provided but Non-Functional, *MR - Meeting Requirement, *NMR - Not Meeting Requirement


The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules, it is recommended to renew the FSC issued vide letter No. F6/DFS/MS/2023/NDZ/120 dated 28.02.2023 under Rule 35(6) of Delhi Fire Service Rules, 2010.

Accordingly, DFA is prepared and put up for perusal, approval and signature please.


23/06/26
Manish Kumar
DO (CD)


23/6/2026
Bhupender Prakash
ADO (CC)


Pl. appear

24/6/26



25/06/26

Spoken on 25/06/26

Amended DFA is put up for your kind perusal and approval.

25/06/26


29/6/26

Principal Director
CFO to


ADCC

30/6/26