

c/34

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI- 110001

No. F.6/DFS/MS/EH/2025/SZ/ 288

Dated: 07/08/2025

FIRE SAFETY CERTIFICATE

Certified that the M/s Hira Sweets and Restaurant at Plot No. E-60, Jawahar Park, Laxmi Nagar, New Delhi- 110092, running at First floor only in a building comprised of basement, ground plus three upper floors, using basement as storage, ground floor (sweet shop), 1st floor (restaurant), 2nd floor (store/office), 3rd floor (office) and terrace tin shed, was issued FSC by this department vide letter No. F.6/DFS/MS/EH/NDZ/2022/224 dated 05.08.2022. The restaurant building was re-inspected by the officer concerned of this department on dated 30.07.2025 in the presence of Mr. Rakesh Tiwari (GM), and found that the restaurant have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the restaurant building/premises (First floor only) is fit for occupancy class Group "D" Assembly Building" w.e.f. 07/08/25 for a period of three years, accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on 07/08/2025 at New Delhi.


07/08/2025
(Virendra Singh)
Chief Fire Officer
Delhi Fire Service
Reg.

Online application Id 2025062510596 dated 08.07.2025

Copy to: - The Executive Engineer (Building), MCD, Civic Centre, Minto Road, New Delhi.

: -for information regarding use of basement.

Conditions for validity of Fire Safety Certificate:-

1. This FSC is valid only for first floor.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
4. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
5. The trained staff should be available round the clock.
6. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
7. Basement strictly shall be used as per BBL. Presently basement used for storage purpose only.
8. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
10. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
11. During inspection terrace was being used for dinning /serving of food as per MCD policy. You may like necessary action as deemed fit.

INSPECTION REPORT

1. Name & address of the building : M/s Hira Sweets and Restaurant at E—60, Jawahar Park, Laxmi Nagar, New Delhi- 110092.
2. Building is comprised of : Basement (storage), ground (sweet shop), 1st floor (restaurant), 2nd floor (store/office), 3rd floor (office) and terrace tin shed.
3. Type of Occupancy : Group D (Assembly) **Restaurant running at 1st floor only**
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/EH/NDZ/2022/224 dated 05.08.2022
6. Fire Safety directives letter No : Nil
7. Date of inspection : 29.07.2025
8. Name of Inspecting Officers : A.D.O. R.K.Yadav (JKP)
9. Name and designation of officers
From the building side : Sh. Rakesh Tiwari (GM)
10. Year of Construction : 2008
11. Applicant's letter No. : MHA Portal ID 2025062510596 dated 08.07.2025

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	12 m N/A N/A	15 m N/A N/A	M/R N/A N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	02 no's 02 no's	02 no's 02 no's	MR MR
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	1.50 m each 1.50 m each	1.50 m each 1.50 m each	MR MR
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	01 No's	Provided	MR
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	1.50 m	1.50 m each	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	N/A 12 ACPH	N/A Natural Ventilation	N/A MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers in restaurant Types IS marking 	16 no.'s ABC/CO ₂ ISI marked	Provided ABC- 04 & Co2- 04 Provided	M/R M/R M/R
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers at each floor Length of hose reel hose Nozzle diameter 	1 Nos. 30 mtrs 5 mm	Provided Provided Provided	M/R M/R M/R

7.	Automatic fire detection and alarming system in restaurant			
	<ul style="list-style-type: none"> Type of detectors Smoke/Heat Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Heat & smoke Required N/A Required N/A	Provided in restaurant Provided Provided Provided Provided	MR N/A N/A N/A N/A
8.	MOEFA	Required	Provided	M/R
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors/Restaurant Sprinkler above false ceiling 	N/A N/A N/A	Provided N/A N/A	N/A N/A N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants Hose Box 	100 MM 01 no's 01 no's	100 MM 01 no's 01 no's	M/R M/R M/R
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A N/A	N/A N/A	N/A N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A 450 LPM 40 m Required Required	N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A 450 LPM 40 m Provided Provided	N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A M/R M/R M/R M/R
14.	Captive Water Storage for fire-fighting			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A N/A N/A N/A 20,000 ltrs	N/A N/A N/A N/A 20,000 ltrs	N/A N/A N/A N/A MR
15.	Exit Signage.	Required	Provided	M/R
16.	Provision of Lifts			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A

N/12

17.	Standby power supply	Required	Provided	M/R
18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found not functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F.6/DFS/MS/EH/NDZ/2022/224 dated 05.08.2022, **renewal under rule 37** of the Delhi Fire Service Rules 2010, **is recommended.**

Accordingly, DFA letter is put up for approval & signature please.

R.K. Yadav
Signature of the Inspecting Officer
Name: - R.K. Yadav
Designation: - ADO (JKP)

~~DO (20)~~ DFA please.

[Signature]
31-7-2025

[Signature]
CF.O/NDZ

[Signature]
01/08/25

[Signature]
CF.O/

[Signature]
4/8/2025

[Signature]
Principal Director

[Signature]
CFD to [Signature]

[Signature]
04/08/25

[Signature]
AD O/(JKP)

[Signature]
5/8/2025

1

P.T.O