



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F6/DFS/MS/WZ/2025/ 2204

Dated: 23/12/2025

To,

Mr. Mohit Narang,
Hitachi Cash Management Services,
Plot No.11, Opp. Punjab Kesari Office, Wazirpur,
New Delhi-110052,

Sub: Issue of FSC in r/o Hitachi Cash Management Services located at Plot No.11, Opp. Punjab Kesari Office, Wazirpur, New Delhi-110052.

Sir,


Kindly reference to letter received in this department through outdoor diary no. 8312 dated 17.11.2025 on the subject cited above. The premise was inspected by the concern nominated authority of this department on 06.12.2025, in presence of Mr. Amit Rana to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for **renewal of FSC is rejected** under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Alternate exit staircase in basement found closed permanently.
2. FCD found removed in basement.
3. Smoke management /ventilation system is found removed in basement and upper floors.
4. Hose reel provided but not functional.
5. Terrace fire pump is found removed.
6. 2500 ltrs Over Head water captive tank provided against the required capacity of 5,000 ltrs.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Forms

Yours faithfully


23/12/25

(S. K. Dua)

Dy. Chief Fire Officer (WZ)
Delhi Fire Service