

C/8

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/School/2025/SZ/ 256

Dated: 22/04/2025

To

The Principal,
Hold Mary's Public School,
C-92, Madangir Village, Delhi 110062

Sub: Regarding issuance of FSC in r/o Hold Mary's Public School, at C-92, Madangir Village, Delhi 110062

Sir,

This has reference to your letter no HMPS/156/2025 dated 19/03/2025 received through outdoor diary no 14749 dated 20/03/2025 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 16.04.2025 in the presence of Mr. Rodrick Chrls (Manger) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. The premise is not accessible to Fire tender/fire engine.
2. There is one staircase having width of 1 mtr against the requirement of two staircase having width of 1.50 mtr each.
3. Exit signage not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)

DIRECTOR

DELHI FIRE SERVICE

Copy to:-

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi 110054.