



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी
अमृत महोत्सव

No. F6/DFS/MS/WZ/School/2025/WZ/285

Dated:- 26/03/2025

FIRE SAFETY CERTIFICATE

Certified that the Holy Child Senior Secondary School, Located at Tagore Garden, New Delhi-110027, comprised of three blocks, 1st block - Ground + 02 Upper Floors, 2nd block - Basement + Ground Floor & New Block - Ground + 02 Upper Floors only, was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/WZ/2022/666 dated 20/06/2022 (for 1st block- Ground plus 02 upper floors & 2nd block- Basement + Ground Floor) & F6/DFS/MS/School/WZ/2022/664 dated 20.06.2022 (for New block- Ground plus 02 upper floors). The said premise was re-inspected by the officer concerned of this department on 12/03/2025 in the presence of Sh. Prakashan P.K (Accountant) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with D.O.E. Cr. No. 262-362 dated 17/01/2005/NBC (Part-IV) and that the school building is fit for occupancy class "Educational Building" Group B" with effect from 26/03/2025 for a period of three years, subject to compliance of the conditions, printed below.

Issued on 26/03/2025 at New Delhi by

(Anil Garg)
Director

Tel No. 011-23414000

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054.
2. The Principal, Holy Child Senior Secondary School, Tagore Garden, New Delhi-110027,

Conditions for the validity of fire safety certificate:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name and address of the building: **Holy Child Senior Secondary School** located at **Tagore Garden, New Delhi-110027**
2. Type of Occupancy : Educational, (1st block-G+02, 2nd block-B+G.F. & New Block-G+02 UFs only)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/WZ/2022/666 dated 20/06/2022
(1st block - G + 02 UFs & 2nd block - B + G)
F6/DFS/MS/School/WZ/2022/664 dated 20/06/2022
(New Block - G + 02 UFs)
5. Fire Safety directives Letter No. : D.O.E. Cr. No. 262-362 dated 17/01/2005 & F6/DFS/MS/BP/2019/01 dated 01/01/2019 (New Block-G+02 UFs)
6. Date of inspection : 12/03/2025
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer
from the building side : Sh. Prakashan P.K (Accountant)
9. Year of Construction : 1967 & 2020-21 (New Block)
10. Applicant's letter No. : email dated 27/01/2025

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirements as per D.O.E. Cr. No. 262-362 dated 17/01/2005/NBC-IV	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	1 st block-02 & New Block-02	1 st block-05 New Block-02	MR
	• Basements	2 nd block-01	2 nd block-02	MR
	b. Width of staircases			
	• Upper floors	1 st block-1.5 m x 2 & New block-1.5 m x 2	1.37 m, 1.38, 1.39 m, 1.22 m & 1.24 m & New Block - 1.5 m x 2	MR
	• Basements	2 nd block-1.5 m x 1	1.08 m & 1.30 m	MR (Old Case)
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	02	Provided	MR
	e. Width Of Corridor	1.5 m	Provided	MR
	f. Door Size	1.0 m (1 st & 2 nd) & 1.20 m (New Block)	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

N-16				
4.	Smoke managements System			
	• Basements	Required	Provided	MR
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	18 nos.	27 nos.	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	1 st block-02 in each floor, 2 nd block-01 in each floor & New Block-01	1 st block-02 in each floor & 2 nd block-01 in each floor & New Block-01	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	Provided	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	100 mm	Provided	MR
	• Number of hydrants per floor	1 st block-02 in each floor 2 nd block-01 in each floor New Block-01	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level	NA	NA	NA
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm & 180 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	25,000 ltrs.	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	5,000 ltrs. (1 st & 2 nd block) & 10,000 ltrs. (New Block)	10,000 ltrs (1 st & 2 nd block) & 15,000 ltrs. (New Block)	MR

	Exit Signage	Required	Provided	MR
15	Exit Signage			
16	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no. F6/DFS/MS/School/WZ/2022/996 dated 07/12/2021 & F6/DFS/MS/School/WZ/2024/653 dated 10/07/2024 renewal under rule 35 of the Delhi Fire Service Rule 2010, is recommended.

Accordingly, DFA is prepared & put up for approval please.

Aman Kumar Lathar
24/03/25
Aman Kumar Lathar
ADO (JWP)

ACFO (JWP)
24/03/2025

24/03/2025

CFD
20/03/2025

Director
21/03/25

ADW V

sig
F.T. letter is put-up for your signature A.

Director
24/03/25

Aman Kumar Lathar
24/03/25
ADO (JWP)