



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2024/ 07

Dated: 02/01/2025

To,

The Authorized Signatory,
Holy Cross Social Service Centre, Dheer Pur,
DDA Project, Near Nirankari Sarovar & ITI,
Delhi-110009.

Sub: - Regarding renewal of fire safety certificate in r/o Holy Cross Social Service Centre located at Dheer Pur, DDA Project, Near Nirankari Sarovar & ITI, Delhi-110009.

Sir,

Please refer to your letter no. nil dated 16.11.2024 received in this department vide outdoor diary no. 10035 dated 06.12.2024 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 28.12.2024 to verify the fire safety arrangements installed in the building as per issued fire safety recommendations vide letter of even no. F6/DFS/BP/2003/768 dated 07.04.2003 at the time of inspection Sr. Jovita D'Souza was also present at site. During the course of the inspection it is observed that the building is comprised of basement, ground & 02 upper floors. Your request for FSC is rejected under Rule 37 (3) due to following shortcomings.

1. Fire check doors found removed at some places.
2. Hose reel hose is provided but not functional.
3. Internal hydrant is provided but not functional.
4. Terrace level firefighting pump capacity of 450lpm is found removed at terrace.
5. Terrace level fire water tank capacity of 20,000ltrs is being used for domestic purposes. Fire water tank must be dedicated to firefighting purposes only.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of this building is at your own risk & responsibility.

Yours faithfully

(Atul Garg)
Director

Ph:-011-23414000

30/12/24