

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

C-20
75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/WZ/EH/2024/ 429

Dated:- 31/12/2024

FIRE SAFETY CERTIFICATE

Certified that the M/s. Honey & Dough (A Unit of Grafters Group), Located at, Property No. 23, Ground Floor, North West Avenue, Club Road, Punjabi Bagh West, Delhi-110026, restaurant is running at Ground Floor only in a building comprised of Basement + Ground + 03 Upper Floors owned/occupied by M/s. Honey & Dough (A Unit of Grafters Group) have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officers concerned of this department on 24/12/2024 in the presence Sh. Jasmeet Singh (Manager) and that the premises is fit for occupancy class "Assembly" Group D (Restaurant) for Ground Floor only with effect from 31/12/2024 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 31/12/2024 at New Delhi by.

(Atul Garg)
Director

Tel No. 011-23414000

Copy to:-

1. The Joint Commissioner of Police (Lic), 1st Floor, Licensing Unit, Police Station, Defence Colony, New Delhi
2. The Dy. Health Officer, Keshav Puram Zone, SDMC, Vishal Enclave, Rajouri Garden, New Delhi-110027.
3. The Authorized Signatory, M/s. Honey & Dough (A Unit of Grafters Group), Property No. 23, Ground Floor, North West Avenue, Club Road, Punjabi Bagh West, Delhi-110026.

Following fire safety directives must be adhered to:-

1. This FSC is valid for restaurant area's Ground Floor only.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
6. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
7. All comments / directions of licensing Department shall always be permitted and followed.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
9. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.
10. The basement shall be used as per BBL.

INSPECTION REPORT

1. Name & address of the building : M/s Honey & Dough (A Unit of Grafters Group), located at Property no. 23, Ground Floor, North West Avenue, Club Road, Punjabi Bagh West, New Delhi-110026
2. Type of Occupancy : Assembly, (Restaurant at Ground Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/EH/WZ/2022/147 dated 31/05/2022 (earlier FSC was issued in the name of M/s. Spize Hospitality (A Unit of Bollywood Biistro))
5. Fire Safety directives letter No : As per UBBL/NBC (Part-IV)
6. Date of inspection : 24/12/2024
7. Name of the Inspecting Officers : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of officers from the building side : Sh. Jasmeet Singh (Manager)
9. Year of Construction : 2014
10. Applicant's Online ID- : 2024120317600 dated 03/12/2024

The said restaurant is running at Ground Floor in a building comprised Basement, Ground Plus Three Upper Floors only.

S. No	Minimum Standards on fire prevention and fire safety U/R 33	UBBL/NBC-IV requirements	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 m	Provided	MR
	• Gate width	N/A	On main road	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-----	-----	-----
	• Upper Floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-----	-----	-----
	• Upper Floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	c. Protection of exits	-----	-----	-----
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	1.5 m each	Provided	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A

4	Smoke Management System.		N/A	N/A
	• Basements	NA	N/A	MR
	• Upper floors	Required	Provided	
5	Fire Extinguishers			MR
	• Total numbers	06 Nos.	Provided	MR
	• Types	ABC, CO ₂ type	Provided	MR
	• IS marking	ISI marked	Provided	MR
6	First-Aid Hose Reels.			MR
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system			N/A
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System			N/A
	• Basement	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			MR
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	01	Provided	MR
12	Yard Hydrants.			N/A
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements			
	• Ground Level	---	----	-----
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level	----	-----	-----
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	40 mts	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR

