



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F6/DFS/MS/WZ/2025/ 397

Dated: 20/08/2025

To,

Mr. Abhijit Dutta,  
Horizon Industrial Products Pvt. Ltd.,  
Plot No.B-4, Badli, Industrial Estate,  
Delhi-110042.

**Sub:** Renewal of FSC in r/o M/s Horizon Industrial Products Pvt. Ltd. Plot No.B-4, Badli, Industrial Estate, Delhi-42.

Sir,

Kindly reference to letter received in this department through outdoor diary no. 3157 dated 23.06.2025 on the subject cited above. The premise was inspected by the concern nominated authority of this department on 28.07.2025, in presence of **Sh. Abhijit Dutta** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for **renewal of FSC is rejected** under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Fire check door found removed.
2. First Aid hose reel found removed on mezzanine and 1<sup>st</sup> floor.
3. Terrace fire pump found non-functional.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:  
[http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/htt](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/htt)  
[p://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](p://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)

Yours faithfully

  
(Virendra Singh)  
Chief Fire Officer  
Delhi Fire Service

