



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

0137



No. F6/DFS/MS/WZ/2025/GH/290
To,

Dated: 13/06/25

Mr. Gunwant Singh,
House No.F-231,
Vishun Garden, Tilak Nagar,
Delhi-110018.

Sub: Issue of FSC in r/o M/s Hotel Aditya Inn (A unit of Gunwant Singh) located at A-27/2, Road No.1, Mahipalpur, Delhi-110037.

Sir,

This is referre to online application no. 2025051708638 dated 17.05.2025, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **01.06.2025**, in presence of **Mr. Gunwant Singh** to ascertain the availability and operability of the fire prevention and fire safety measures. The following shortcomings were observed:

1. Accessible road on which building abuts is less than 6mtr.

In this regard as stipulated in sub Rule (5) of Rule 35 of DFS Act-2007 & Rules 2010 it is advised the applicant to apply with a fresh application for grant of fire safety certificate under sub-rule (2) on Form "I"/MHA Portal and it shall be accompanied with a certificate from the architect and owner or occupier that all the fire prevention and fire safety measures are duly complying with the requirements as communicated under sub-rule (4) above, for further consideration in this regard. The web links for DFS Act-2007/ Rules 2010 & Form "I" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours faithfully

12 61 2025

(Virendra Singh)
Chief Fire Officer

Copy to:

1. MCD Portal ID-2025051708638 dated 17.05.2025