



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव


No. DFS/MS/GH/SZ/2025/378

Dated:- 28/05/2025

FIRE SAFETY CERTIFICATE

Certified that the **M/s. Hotel Aman**, Located at **Plot No. 5, Kh. No. 404, Block-A, Mahipalpur Road No. 4, Delhi-110037**, guest house is running at ground + 03 upper floors only in a building comprised of basement (closed), ground (03 guest rooms) + 1st to 3rd floor (08 guest rooms on each floor) + 4th Floor (not in use), owned/occupied by **M/s. Hotel Aman** have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 16/05/2025 in the presence of Sh. Sunny Sehrawat (Owner) and building/Premises is fit for occupancy **"Residential Building" Group A for guest house, ground (03 guest rooms) 1st to 3rd floor (08 guest rooms at each floor) Total 27 guest room only** with effect from 28/05/2025 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010 printed below.

Issued on 28/05/2025 at New Delhi by


28/05/2025
(Virendra Singh)
Chief Fire Officer

Copy to:-

1. The Commissioner, Municipal Corporation of Delhi, Civic Centre, Minto Road, New Delhi-110002 :- in r/o computer id no. 2025042807410 dated 29/04/2025
2. The Joint Commissioner of Police, Licensing unit, 1st Floor, Police Station, Defence Colony, New Delhi.
3. The Authorized Signatory, Hotel Aman, Plot No. 5, Kh. No. 404, Block-A, Mahipalpur Road No. 4, Delhi-110037.

Conditions for validity of Fire Safety Certification:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.
9. The guest house management has given an undertaking that basement floor closed shall not be used for any purpose & above 3rd floor shall not be used for any purposes, if found using their FSC shall be treated as null and void.

INSPECTION REPORT

1. Name & address of the building: Hotel Aman, located at Plot No. 5, Kh. No. 404, Block-A, Mahipalpur Road No. 4, Delhi-110037.
2. Type of Occupancy : Residential, Sub Division A-1, the said building is comprised of basement, ground plus 04 upper floors but guest house is running at ground + 03 upper floors only, ground (03 guest rooms), 1st to 3rd floor (08 guest rooms at each floor) Total 27 guest rooms only.
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 16/05/2025
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer from the building side : Sh. Sunny Sehrawat (Owner)
9. Year of Construction : 2004
10. Applicant's online application no. : 2025042807410 dated 29/04/2025

S No	Minimum standards on fire prevention and fire safety U/R 33	UBBL/NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 m	Provided	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 m each	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	02	Provided	MR
	e. Width Of Corridor	1.5 m	Provided	MR
	f. Door Size (final exit)	1.5 m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural/Exhaust Fan	MR

(Signature)

5.	Fire Extinguishers			
	• Total numbers	10 nos.	Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• ISI marking	Required	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	01	Provided	NA
	• Length of hose reel hose	30 m	Provided	NA
	• Nozzle diameter	05 mm	Provided	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	CO type	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	NA	Provided	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm	Provided	MR
	➤ Head of the pump	40 mtrs.	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for firefighting:			
	• Underground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	5,000 ltrs.	10,000 ltrs.	MR
15	Exit Signage	Required	Provided	MR

16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Note:- The guest house management has given an undertaking that basement floor closed and shall not be used for any purpose if found using our FSC may be treated as null and void. Further also undertake that floors above 3rd floor shall not be used for any purposes.

The fire protection systems provided in the building were checked and found functional at the time of inspection. Shortcomings issued vide letter no. F6/DFS/MS/GH/NDZ/87 dated 18/02/2025 found rectified.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety requirements under the rules, grant of Fire Safety Certificate is recommended under rule 35 of the Delhi Fire Service Rules, 2010 under the DFS Act 2007.

Accordingly DFA is prepared & put up for your approval please.

Aman Kumar Bathar
ADO (JWP)

DO (SP)

CFD (MS)

22/5/2025

Director

22/5/25

ADJUN

Sir, F.I. letter is put-up for your signature 15/5/25

Director M/R

CFD

22/5/25

MS cell

22/5/25

22/5/25