



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001**



No. F.6/DFS/MS/C&CN/EH/2026/ 748

Dated: 30/07/2026

To,  
The Commissioner,  
MCD, Civic Centre, Minto Road,  
New Delhi-110002

**Sub:** Issue of Fire Safety Certificate in r/o M/s Hotel Amazing Inn located at WZ-4203-C, Sant Nagar, Shakur Basti, Delhi-110034.

Sir,

Please refer to your online application no. 2026062309221 dated 23.06.2026, received in this department on the subject cited above. In this connection, it is to inform that premises was inspected by this officers concerned of this department on 15.07.2026 in the presence of Mr. Kaushal (Manager) and observed that the building comprised of Ground + 03 upper floors.

**Following shortcomings were observed during time of inspection:**

1. Single staircase having width 1 mtr is provided against the required two staircases of 1.5 mtr width each.
2. Width of Corridor is 1.1 mtr against the required width of 1.8 mtr.
3. Terrace tank and pump not accessible as staircase is sealed at terrace level. Therefore, could not be inspected.
4. Smoke management system not provided.
5. Detector system found not functional & MOEFA is not provided.
6. Internal hydrants found not functional & hose reel is not provided.
7. 3<sup>rd</sup> floor found sealed at time of inspection.

In this regard as stipulated in sub Rule (5) of Rule 35 of DFS Act-2007 & Rules 2010 you may advise the applicant to apply with a fresh application for grant of fire safety certificate under sub-rule (2) on Form "I" and it shall be accompanied with a certificate from the architect and owner or occupier that all the fire prevention and fire safety measures are duly complying with the requirements as communicated under sub-rule (4) above, for further consideration in this regard. The web links for DFS Act-2007/ Rules 2010 & Form "I" are as under:

[http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)

Yours faithfully

(S. K. Dua)

Chief Fire Officer  
Delhi Fire Service

Copy To:-

1. MCD Portal Id- 2026062309221 dated 23.06.2026.