

c/m/s

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

NO.F.6/DFS/MS/GH/2026/ 349

Dated: 1-12-2026
22/04/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Dr. SPM Civic Center, Minto Road,
New Delhi- 110002.

Sub - Reply of application regarding FSC/NOC in r/o M/s Hotel Arch Plaza, 91, Bijwasan Road, Kapashera, New Delhi 110037.


Sir,

This has a reference to online ID- 2026032503572 Dt. 26/03/2026 on the subject cited above. In this connection, it is to inform you that the premise was visited by the officer concerned of this department on 11/04/2026 in the presence of Mr. Trilok Singh (Manager). During course of inspection, the shortcomings observed are as below: -

1. First-Aid Hose Reels found non-functional.
2. Automatic detection and alarm system found non- functional.
3. MOEFA found non-functional.
4. Automatic sprinklers system in basement found nonfunctional.
5. Terrace pump is provided but found non-functional.
6. Auto starting of terrace pump found non-functional.
7. There is a temporary structure found erected at the terrace of 3rd floor of the building and it is being used for Banquet Hall purposes, which is not permitted as per applicable norms.

In view of the above, application for fire safety certificate is rejected. You are requested to rectify the above shortcomings under intimation to this department for further action in the matter. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of owner/occupier of the establishment. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(A. K. Malik)
Chief Fire Officer
9/2

Copy to: -

1. Mr. Trilok Singh (Manager), M/s Hotel Arch Plaza, 91, Bijwasan Road, Kapashera, New Delhi 110037.