

c/67

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/GH/2025/SZ/ 92

Dated: 18/02/2025

To,

The Joint C.P. (LIC.),
1st floor, Police Station,
Defense Colony, New Delhi.

Sub: -Regarding renewal of "FSC" from fire safety point of view in r/o M/s Hotel Aura Guest House at 1185/31, Arakashan Road, Pahar Ganj, New Delhi.

Sir,

Please refer to online application ID 2025012200901 dated 23.01.2025, on the subject cited above. In this connection, it is to inform you that officer concerned of this department inspected the aforesaid guest house building on dated 07.02.2025 in presence of Mr. Pardeep (Manager), to verify the fire safety arrangements in accordance with the rules.

At the time of inspection, it was observed that the above said guest house building comprised of basement (vacant), ground floor (reception & 04 guest rooms), 1st floor to 3rd floor (07 guest rooms at each floor) (total 25 guest rooms only), and have following shortcomings: -

1. Fire Check door found not provided.
2. Exit Signages found removed at some places.

Keeping in view of above, issuance of fire safety certificate can-not be considered at this stage. Management of the guest house may be requested to rectify the above said shortcomings for taking further necessary action in this matter under intimation to this department and running guest house in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier.

Yours faithfully,

(Anil Garg)
Director
Delhi Fire Service

Copy to: -

1. The Owner/Occupier, M/s Hotel Aura Guest House at 1185/31, Arakashan Road, Pahar Ganj, New Delhi.