

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/GH/2025/SZ/255
To

Dated: 24/05/2025

The Joint Commissioner of Police,
1st Floor, P.S Defence Colony,
New Delhi 110049

Sub: Regarding issuance of FSC in r/o M/s Hotel Ramhan located at 3/1 East Patel Nagar, New Delhi 110008

Sir,

This has reference with **MCD Portal ID No 2025042607314 dated 26/04/2025** on the subject cited above. In this connection, it is to inform you that the premise have been inspected by officer concerned of this department on 20.05.2025 in presence of Mr. Danu (Manager) to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

1. MOEFA not working.
2. Overhead water tank capacity 10,000 ltrs draw a domestic connection.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

01/06/25