

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/GH/2025/SZ/ 313
To

Dated: 01/07/2025

The Joint Commissioner of Police,
1st Floor, P.S Defence Colony
New Delhi 110049.

Sub: Regarding issuance of NOC in r/o M/s Hotel Ravin at Plot No A-383, NH-08,
Mahipalpur Extn., New Delhi- 110037

Sir,

This is in reference with **Online ID No 2025060509676 dated 05/06/2025** on the subject cited above. In this connection, the premises have been inspected by officer concerned of this department on 27.06.2024 in the presence of Mr. Gourav (Manager) to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

- 1 Smoke Management provided but found non-functional.
- 2 Carbon Monoxide detector provided but found non- functional.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

dn e