



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/GH/2024/SZ/ 17

Dated: 09 / 01 / 2025

To

The Joint Commissioner of Police (Lic.),
1st Floor, P.S. Defense Colony
New Delhi-110049

Sub: Inspection report in r/o M/s Hotel Rest Point located at Prop. No. 7923, Arakashan Road, Pahar Ganj, New Delhi-110055

Sir,

This has reference to online application No. 2024122318285 dated 23/12/2024. In this connection, it is to inform you that the said premise was inspected by the officer concerned of this department on dated 26/12/2024 in the presence of Sh. Dinesh Kumar (Proprietor) of the guest house, from fire & life safety point of view. During the inspection, the shortcomings observed are as below.

1. Waste material stored at terrace and loose electric wires seen at some places.
2. 4th Floor being used for guest house purpose, despite an affidavit regarding not to use any floor above third floor.

In view of the above, the application for renewal of fire safety certificate is rejected. **It is requested that operation of guest house may be stopped immediately in view of the violation of affidavit dated 13.11.2019 regarding not to use any floor above 3rd floor.** The occupancy of the premises in the absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The local/licensing authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

T. No. 011-23414000

o/c

Copy to: -

1. Authorized Signatory M/s Hotel Rest Point located at Prop. No. 7923, Arakashan Road, Pahar Ganj, New Delhi-110055