

460

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/GH/NDZ/ 61

Dated:-03/02/2025

To,

The Manager,  
M/s Hotel Royal Gold Palace,  
Sarg Infratech Private Limited,  
7A/10-11, W.E.A, Channa Market,  
Karol Bagh, New Delhi.

**Sub:** Regarding issuance of FSC in r/o M/s Hotel Royal Gold Palace, Sarg Infratech Private Limited,  
7A/10-11, W.E.A, Channa Market, Karol Bagh, New Delhi.

Sir,

This has reference to online id no. 2025011700673 dated 17/01/25, on the subject cited above. In this connection, it is to inform you that the site was inspected by the officer concerned of this department on 28/01/25 in the presence of Mr. Kuldeep (care taker) and following shortcomings were observed:-

1. Fire Check Doors not provided as per Gazette notification 2019.
2. Smoke management system not provided as per Gazette notification 2019
3. Co detector found non functional.

Hence, the case is rejected and Fire Safety Certificate (FSC) cannot be renewed at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter

Yours faithfully,

  
(Atul Sarg)  
DIRECTOR  
Delhi Fire Service  
a-60  
391

**Copy to :-**

1. The Commissioner, MCD, Civic Centre, New Delhi.
2. The Addl. Commissioner of Police (Lic.) First floor, PS Defense Colony, New Delhi.