



C/99

75  
Azadi Ka  
Amrit Mahotsav

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/GH/2025/SZ/ 132

Dated: 25/03/2025

To

The Joint Commissioner of Police (Lic.),  
1<sup>st</sup> Floor, P.S. Defense Colony  
New Delhi-110049

**Sub: Inspection report in r/o M/s Hotel Sagar Palace (Guest House) situated at 1332, Chowk Sangtrashan, Gali Dispensary Wali, Pahar Ganj, New Delhi-110055**

Sir,

Please refer to online application Id. 2025030702983 dated 07/03/2025. In this connection, it is to inform you that the said premise was inspected by the officer concerned of this department from fire safety point of view on dated 15/03/2025 in the presence of Sh. Mohd. Mazhr (Manager) of the guest house. During course of inspection, the shortcomings observed are as below.

1. First aid hose reel found removed.
2. Terrace level fire pump was not on auto mode.

In view of the above, the application for issuance of fire safety certificate is rejected. The occupancy of the premises in the absence of requisite fire safety certificate/arrangements shall be at the risk and liability of the owner/occupier. The local/licensing authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

T. No. 01123414000

Copy to: -

1. Authorized Signatory M/s Hotel Sagar Palace (Guest House) situated at 1332, Chowk Sangtrashan, Gali Dispensary Wali, Pahar Ganj, New Delhi-110055