



C-5

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

NO.F.6/DFS/MS/WZ/GH/2025/ 336

Date: 31 / 07 / 2025

To

Sh. Manish Mavi,
House No-C-81,
Loni Dehat Ghaziabad, Lal Bagh,
Ghaziabad, Utter Pradesh-201102.

Sub:- Issue of fire safety certificate r/o M/s Hotel Samrat located at F-22/A F-Block, Dayal Pur Main Karawal Nagar Raod, Delhi-110094.

Sir,

This is reference to online application no. 2025062810693 dated 01.07.2025, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **15.07.2025**, in presence of **Sh. Manish Mavi** to ascertain the availability and operability of the fire prevention and fire safety measures. The following shortcomings were observed:

1. The width of Staircase is 0.80 x 2 mtr against the required width of two staircase 1.5 mtr each.
2. The width of corridor is 1.15 mtr against the required width of 1.8 mtr.
3. 08 fire extinguishers of ABC type are not provided.
4. First Aid hose reel not provided.
5. CO detector system & location of main panel not provided.
6. MOEFA is not provided.
7. Terrace Fire pump with capacity of 450 LPM not provided.
8. An overhead water storage tank capacity of 10,000 ltr is not provided.
9. The required exit signage are not provided.
10. Standby power supply not provided.
11. 3rd floor found hall without any fire protection system.

In this regard as stipulated in sub Rule (5) of Rule 35 of DFS Act-2007 & Rules 2010 it is advised the applicant to apply with a fresh application for grant of fire safety certificate under sub-rule (2) on Form "I"/MHA Portal and it shall be accompanied with a certificate from the architect and owner or occupier that all the fire prevention and fire safety measures are duly complying with the requirements as communicated under sub-rule (4) above, for further consideration in this regard. The web links for DFS Act-2007/ Rules 2010 & Form "I" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours faithfully

(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to:

1. MHA Portal ID-2025062810693 dated 01.07.2025