



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

d/66
7/5
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/GH/NDZ/2025/ 244

Dated: 20/05/2025

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

Ref: elt.mcdonline application no. 2025050708082

Sub: Regarding renewal of Fire Safety Certificate in respect of M/s **Hotel Sapphire** located
at **87, Krishan Gali, Pahar Ganj, New Delhi.**

Sir,

With reference to the elt.mcdonline application no. 2025050708082 on the subject cited above, it is informed that the said guest house was inspected by the officer concerned of this department on. 15.05.2025 in the presence of Mr. Ansh Thakur (Manager) and following shortcoming were observed at the time of inspection.

1. Hose reel found non functional.
2. CO detector found non functional.
3. Fire pump found non functional.
4. Auto start mechanism of fire pump was found removed.

In view of above shortcomings, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

15/5/25. 16/5/25