



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

C-111 

No.F.6/DFS/MS/NDZ/GH/2025/136

Dated: 26/03/2025

To,

The Joint Commissioner of Police (Lic.),  
1<sup>st</sup> floor Police Station Defence Colony,  
New Delhi

**Subject:-Regarding renewal of Fire Safety Certificate in r/o M/s Hotel Sehej Inn, 51/3, New Market,  
WEA, New Rohtak Road, Karol Bagh, New Delhi-110005.**

Sir,

This has reference to MCD application ID No. 2025022502407 dated 27/02/2025 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department have carried out the inspection of the above mentioned guest house from fire safety point of view in presence of Sh. Hansraj, Manager on dated 22/03/2025. The building comprised of basement, ground plus three upper floors. The following shortcoming was observed during the time of inspection.

1. Fire check door not provided.
2. First-Aid Hose reels are provided but not functional.
3. MOEFA is provided but not functional.
4. Automatic sprinkler system is provided but not functional.
5. Terrace pump capacity 450 lpm head 30 meter is provided but not functional.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit..

Yours faithfully

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

  
24/3