



75  
Azadi Ka  
Amrit Mahotsav

C/112

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/GH/2025/SZ/ 282

Dated: 09 / 06 / 2025

To

The Joint Commissioner of Police (Lic.),  
1<sup>st</sup> Floor, P.S. Defence Colony,  
New Delhi-110049

**Sub: Inspection report in r/o M/s Hotel Shubham Vilas located at A-42, Vishal Enclave, Rajouri Garden, New Delhi-110027**

Sir,

Please refer to online portal Id. No. **2025052108819** dated 21/05/2025. In this connection, it is to inform you that the said premise was inspected by the officer concerned of this department from fire safety point of view on dated 28/05/2025 in the presence of Ms. Vini (Manager) and the shortcomings observed are as below.

1. First aid hose-reel provided found non-functional.
2. Terrace fire pump provided found non-functional.
3. Lift signage found removed.
4. Temporary structure found erected on terrace, same shall be removed.

In view of the above, the application for issuance of fire safety certificate is rejected. The occupancy of the premise in the absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The local/licensing authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
6/6/2025  
(Virendra Singh)  
Chief Fire Officer  
Delhi Fire Service

Copy to: -

1. Sh. Amit Chadha, M/s Hotel Shubham Vilas located at A-42, Vishal Enclave, Rajouri Garden, New Delhi-110027