



c/1116



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F6/DFS/MS/GH/SZ/2026/ 370

Dated: 17/04/2026

FIRE SAFETY CERTIFICATE

Certified that the M/s Hotel Star, located at A-288, NH-48 Mahipalpur, New Delhi 110037, in the building comprised of Basement, Ground+03 upper floors. Owned/occupied by M/s Hotel Star, was earlier issued Fire Safety Certificate by this department vide letter no- F.6/DFS/MS/GH/2023/SZ/101. dated 02/06/2023, for ground and 03 upper floors. The premises was re-inspected by the officer concerned of this department on 09/04/2026. in the presence Sh. Inderjeet Sehrawat and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premise is fit for occupancy class "Residential" "Group-A" (Guest House)(ground floor – reception and 06 guest rooms, 1st floor-09 guest rooms, 2nd floor-09 guest rooms & 3rd floor –09 guest rooms), total 33 guest rooms, and validity up to 31/03/2029 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010. Conditions mentioned below.

Issued on17/04/2026 at New Delhi by.


16/4/26
(A.K. Malik)
Chief Fire Officer
old SH

Copy to:

1. The Commissioner MCD, Civic Centre, Minto Road, New Delhi- 110002.-to ensure the occupancy as detailed above & deviation if any.
2. The authorized signatory M/s Hotel Star, Situated at A-288, NH-48 Mahipalpur, New Delhi 110037. (Online Portal ID No.2026032603622 dated- 26/03/2026.)

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management/occupier.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc. shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.
9. Basement shall be used as per building bylaws strictly.

INSPECTION REPORT				
1. Name & address of the building	M/s Hotel Star, located at A-288, NH-48 Mahipalpur, New Delhi 110037.			
2. Type of Occupancy	Residential, "Group-A" (Guest House), Basement, Ground+03 upper floors. (ground floor – reception and 06 guest rooms, 1 st floor-09 guest rooms, 2 nd floor-09 guest rooms & 3 rd floor –09 guest rooms), total 33 guest rooms.			
3. Type of Case	Renewal			
4. Details of Previous NOC	F.6/DFS/MS/GH/2023/SZ/101 dated 02/06/2023.			
5. Fire Safety directives letter No	Nill			
6. Date of inspection	09/04/2026			
7. Name of Inspecting Officer	Sh. Sarabjeet Singh ADO (BCP)			
8. Name and designation of officers From the building side	Sh. Inderjeet Sehrawat.			
9. Year of Construction	2000 (As per online application)			
10. Applicant's letter No.	Online-ID No – 2026032603622 dated- 26/03/2026.			
S. No	Minimum Standards on fire prevention and fire safety U/R 33	BBL/NBC/ Rule 35(6) of DFS Rule 2010	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	12 mtr Required	12 mtr Provided	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02 Nos	02 Nos	MR
	• Basements	02 Nos	02 Nos	MR
	b. Width of staircases			
	• Upper Floor	1.25m & 1.50m	1.25 mtr & 1.20 mtr	MR (old case)
	• Basements	1.25m & 1.50m	1.25 mtr & 1.20 mtr	MR (old case)
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No. of continuous staircases to terrace	02 Nos Required	02 Nos Provided	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1m	1.70 m (Final Exit)	MR
3.	Compartmentation			
	a) Fire check door	NA	NA	NA
	b) Sealing of electrical shafts	NA	NA	NA
	c) Fire Rating of shaft door	NA	NA	NA
	d) Water Curtain	NA	NA	NA
	e) Fire Dampers	NA	NA	NA
4.	Smoke Management system.			
	a) Basements	Required	Exhaust fan provided	MR
	b) Upper floors	Required	Exhaust fan provided	MR
5.	Fire Extinguishers.			
	a) Total numbers	15	15 Nos Provided	MR
	b) Types	ABC/CO2	ABC/CO2	MR
	c) IS marking	ISI market	Provided	MR
6.	First Aid Hose Reels.			
	a) Total numbers on each floor	One at each	Provided	NMR
	b) Length of hose reel hose	30mm	Provided	MR

	c) Nozzle diameter	5m	Provided	
7.	Automatic fire detection & alarming system. As per clause 7.31 in UBBL-2016			
	a) Type of detectors	Co/Smoke.	Co/Smoke/Heat	MR
	b) Location of Main Panel	Required	Ground Floor	MR
	c) Location of Repeater Panel	NA	NA	NA
	d) Alternate source of power	Required	Provided	MR
	e) Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	Provided	MR
10.	Automatic Sprinkler System		NA	NA
	a) Basement	Required	Provided	MR
	b) Ground & Upper Floors	NA	NA	NA
	c) Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	a) Size of riser/down-comer	100 mm	100mm	MR
	b) Number of hydrants per floor	01 Nos	01 Nos	MR
	c) Hose Box	01 Nos	01 Nos	MR
12.	Yard Hydrants			
	a) Total number of hydrants	NA	NA	NA
	b) Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	Terrace level			
	➤ Discharge of pump	450 LPM	450 & 180 LPM	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltrs	10,000 ltrs	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of Lift Shaft	NA	NA	NA
	b) Pressurization of Lift lobby	NA	NA	NA
	c) Communication In lift Car	NA	NA	NA
	d) Fireman's Grounding Switch	NA	NA	NA
	e) Lift Signage	NA	NA	MR
17.	Standby power supply	Required	Provided (DG Set)	

W/39


18.	Refuge Area.			
	a) Total Area			
	b) Location	NA	NA	NA
19.	Fire Control Room	NA	NA	NA
	a) Detector System Panel	NA	NA	NA
	b) Flow Switch Panel	NA	NA	NA
	c) PA System Panel	NA	NA	NA
	d) Battery backup	NA	NA	NA
	e) Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F.6/DFS/MS/GH/2023/SZ/101, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signatures please.

Last Date of Disposal 24/04/2026.


Name - Sarabjeet Singh
Designation - ADO(BCP)

DO (SD) 
13/4/26
Ravinder Singh

~~CFD/24~~

13/4/26
A.K. MALIK


Principal Officer

CFD to Sd/-


12/04/26


Principal Officer