



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/5
आपदा की
अमृत महोत्सव

No. F6/DFS/MS/GH/SZ/2025/120

Dated: 18/03/2025

To

The Joint Commissioner of Police,
Office of Joint Commissioner of Police: Licensing,
1st Floor, P. S Defence Colony, New Delhi.

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s Hotel Silver Saffron located at Property no. A -1-4, A – Block, Paschim Vihar, New Delhi.

Sir,

With reference to the etl.mcdonline application no. 2025022702534 on the subject cited above, it is informed that the said building was inspected by officer concerned of this department on 06.03.2025 in the presence of Mr. Kamalpreet Singh Grewal (Owner) and following shortcomings were observed.

1. Pressure in the downcomer system is not meeting the requirements.
2. Terrace tank capacity of 15,000 liters for firefighting has not been provided.
3. Access to Terrace tank has not been provided.
4. Kitchen at upper ground floor must be removed.

In view of above shortcomings, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)
Director

Delhi Fire Service

07/03/25

10/3