

car

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/GH/NDZ/ 08

Dated:-03/01/2025

To,

The Manager  
M/S Hotel Sun City Deluxe ,  
11A/34 Strret, WEA Channa Market,  
Karol Bagh, New Delhi.

**Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Hotel Sun City Deluxe located at 11A/34 Strret, WEA Channa Market, Karol Bagh, New Delhi.**

Sir,

This has reference to online ID No. 2024120317611 dated 05/12/24 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 02/01/25 in the presence of Mr. Amit , Manager and following shortcomings were observed:-

1. Basement is under renovation .
2. Fire check doors are not provided.
3. Further, restaurant is running at ground floor and same is not shown at building plan.

Hence, the case is rejected and Fire Safety Certificate (FSC) cannot be renewed at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,

  
(Atul Garg)  
DIRECTOR  
Delhi Fire Service

Copy to:

1. Addl. Commissioner of Police( lic), 1st floor, Defence Colony Police Station, New Delhi