

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/GH/2025/WZ/ 456

Dated: 24/11/2025

To,

The Commissioner,  
Municipal Corporation of Delhi,  
Dr. SPM Civic Centre, JLN Marg,  
Minto Road, New Delhi-110002.

Sub: Application for grant of fire safety certificate for Hotel Sunberry, D-14, Prashant Vihar, Sector 14, Delhi-110085.

Sir,

This has a reference to online ID- **2025101414193** dated 14/10/2025 on the subject cited above. In this connection, it is to inform you that the premise was visited by the officer concerned of this department on 04/11/2025 in the presence of Sh. Joginder Singh (owner). During course of inspection, the shortcomings observed are as below: -

1. First-Aid Hose Reels found non-functional.
2. Automatic fire detection and alarming system found non-functional.
3. MOEFA found provided but found non-functional.
4. Public Address System found non-functional.
5. Internal Hydrants also found non-functional.
6. Terrace pump of capacity 450 lpm is provided but found non-functional.
7. Terrace fire pump is also not on auto mode.

In view of the above, application for fire safety certificate is rejected. You are requested to rectify the above shortcomings under intimation to this department for further action in the matter. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of owner/occupier of the establishment. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(Dr. S. K. Tomar)  
Dy. Chief Fire Officer, NDZ  
Delhi Fire Service

h