



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001



No. F6/DFS/MS/2026/CN/Restaurant/ 648

Dated: 24.07.2026

FIRE SAFETY CERTIFICATE

Certified that the M/s Hotel Sun Shine Place located at Property No.957, 4 Naiwala Bank Street, Karol Bagh, New Delhi-110055, comprised of basement, ground + 05 upper floors, Basement (Vacant), Ground floor (reception + 01 office) and 1st to 3rd floor (04 guest rooms at each floor) Total -12 guest room only, 4th floor & 5th floor not in use as per affidavit dated 26.10.2019. The FSC was earlier granted by this department vide letter No. F.6/DFS/MS/GH/2023/81 dated 03.05.2023. The premises was re-inspected by the team of officers concerned of this department on 15.07.2026 in the presence of Mr. Pawan Chawla and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class "Residential Building" (Sub Division-A-1) with effect from 24.07.2026 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 24.07.2026 at New Delhi by



(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service



Copy to: -

1. The Commissioner, MCD, Civic Center, New Delhi: to kindly ensure the occupancy as detailed above and deviation in construction if any: MCD Portal Id-2026071009686 dated 10.07.2026.
2. The Authorized Signatory, M/s Hotel Sun Shine Place located at Property No.957, 4 Naiwala Bank Street, Karol Bagh, New Delhi-110055.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on .
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building	M/s Hotel Sun Shine Place located at Property No.957, 4 Naiwala Bank Street, Karol Bagh, New Delhi-110055.			
2. Type of Occupancy	Residential, "Group-A" (Guest House)			
3. Comprised of building	Basement, Ground + 05 upper floors			
4. Type of Case	Renewal (Guest House is running at Ground+03 upper floors, Total-12 guest rooms) Basement-Vacant Ground-Reception + 01 office 1st floor-04 guest rooms 2nd floor-04 guest rooms 3rd floor-04 guest rooms 4 th & 5 th floor- Not in sue (as per affidavit dated 04.04.2026) Total-12 guest rooms only			
5. Details of Previous NOC	F.6/DFS/MS/GH/2023/81 dated 03.05.2023			
6. Fire Safety directives letter No	-NA-			
7. Date of inspection	15.07.2026			
8. Name of Inspecting Officer	Sh. Ajay Kumar Sharma ADO (Karol Bagh)			
9. Name and designation of officers From the building side	Mr. Pawan Chawla			
10. Year of Construction	1993 on MCD Portal			
11. Applicant's letter No.	Online application No.2026071009686 dated 10.07.2026.			
S. No	Minimum Standards on fire prevention and fire safety U/R 33	Requirement/Existing Fire safety arrangement (Rule 35 (6))	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	12m	MR
	• Gate width	-NA-	-NA-	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01nos.	01nos	MR (Old case)
	• Basements	-NA-	-NA-	-NA-
	b. Width of staircases			
	• Upper Floor	1.25m	1.20m	MR (Old case)
	• Basements	-NA-	-NA-	-NA-
	c. Protection of exits			
	• Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	01nos.	01nos.	MR
	e. Width of Corridor	1m	1.33m	MR
	f. Door Size	1m	0.81 x 200cm	MR (Old case)
3.	Compartmentation			
	a) Fire check door	-NA-	-NA-	-NA-
	b) Sealing of electrical shafts	-NA-	-NA-	-NA-
	c) Fire Rating of shaft door	-NA-	-NA-	-NA-
	d) Water Curtain	-NA-	-NA-	-NA-
	e) Fire Dampers	-NA-	-NA-	-NA-
4.	Smoke Management System			
	a) Basements	-NA-	-NA-	-NA-
	b) Upper floors	Required	Provided	MR
5.	Fire Extinguishers			

	a) Total numbers	02nos.at each floor	Provided	MR
	b) Types	ABC/CO2	ABC/CO2	MR
	c) IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	a) Total numbers on each floor	01nos.	Provided	MR
	b) Length of hose reel hose	30mm	Provided	MR
	c) Nozzle diameter	5m	Provided	MR
7.	Automatic fire detection and alarming system			
	a) Type of detectors	CO	Provided	MR
	b) Location of Main Panel	Ground floor	Provided	MR
	c) Location of Repeater Panel	-NA-	-NA-	-NA-
	d) Alternate source of power	Required	Provided	MR
	e) Hooters' Location	At each floor	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	a) Basement	-NA-	-NA-	-NA-
	b) Ground & Upper Floors	-NA-	-NA-	-NA-
	c) Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants			
	a) Size of riser/down-comer	-NA-	-NA-	-NA-
	b) Number of hydrants per floor	-NA-	-NA-	-NA-
	c) Hose Box	-NA-	-NA-	-NA-
12.	Yard Hydrants			
	a) Total number of hydrants	-NA-	-NA-	-NA-
	b) Hose Box	-NA-	-NA-	-NA-
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	-NA-	-NA-	-NA-
	➤ Head of Main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey Pump out put	-NA-	-NA-	-NA-
	➤ Jockey pump head	-NA-	-NA-	-NA-
	➤ Standby Pump out put	-NA-	-NA-	-NA-
	➤ Standby Pump Head	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	Terrace level			
	➤ Discharge of pump	450lpm	Provided	MR
	➤ Head of the pump	30m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	-NA-	-NA-	-NA-
	➤ Draw-off connection	-NA-	-NA-	-NA-
	➤ Fire service inlet	-NA-	-NA-	-NA-
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	5,000ltr	Provided	MR
15.	Exit Signage.	Required	Provided	MR

6.	Provision of Lifts.			
	a) Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	b) Pressurization of Lift lobby	-NA-	-NA-	-NA-
	c) Communication In lift Car	Required	Provided	MR
	d) Fireman's Grounding Switch	Required	Provided	MR
	e) Lift Signage	Required	Provided	MR
7.	Standby power supply	Required	Provided	MR
8.	Refuge Area.			
	a) Total Area	-NA-	-NA-	-NA-
	b) Location	-NA-	-NA-	-NA-
19.	Fire Control Room			
	a) Detector System Panel	-NA-	-NA-	-NA-
	b) Flow Switch Panel	-NA-	-NA-	-NA-
	c) PA System Panel	-NA-	-NA-	-NA-
	d) Battery backup	-NA-	-NA-	-NA-
	e) Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part-4, and removal of shortcomings issued vide letter no. **351 dated 22.04.2026**, the FSC issued vide letter no. **F.6/DFS/MS/GH/2023/81 dated 03.05.2023**, renewal of FSC under rule 37 of the Delhi Fire Service Rules, 2010 is **recommended**.

Signature of the Inspecting Officer
Name **Ajay Kumar Sharma**
Designation **ADO(Karol Bagh)**

DO (CD)

Principal Director

CFO to issue.

ADO/KB

FT letter is put up for perusal and signature please