clion

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI <u>HEAD QUARTERS</u>: <u>DELHI FIRE SERVICE</u>: <u>NEW DELHI</u> – 110001

No.F6/DFS/MS/GH/NDZ/ 16

Dated:08/01/2025

To,

The Manager, M/S Hotel Surya International, 4/33 WEA, Saraswati Marg, Karol Bagh, New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Hotel Surya International, 4/33 WEA, Saraswati Marg, Karol Bagh, New Delhi.

Sir.

This has reference to on line ID No. 2024122418361 dated 25.12.2024, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned of this department on 02/01/2025 in the presence of Mr. Sumit and following shortcomings were observed: -

 Fire Check doors are required to be provided at the staircase as per gazette notification dated 27.05.2019 as the number lodger is more than 10 at first and second floor as mentioned in application form.

2. Building plan is not uploaded on the online portal.

In view of above, the case is rejected and FSC issued earlier vide letter no. F6/DFS/MS/GH/SZ/2022/528 dated 05.12.2022 shall stand null and void. Therefore, you are requested to comply the same for further consideration in the matter.

Yours faithfull

01123414000

Copy to:-

1. The Addl. Commissioner of Police (Lic.) First floor, PS Defence Colony New Delhi. :for information and n/a and FSC issued earlier vide letter no. F6/DFS/MS/GH/SZ/2022/528 dated 05.12.2022 shall stand null and void.