

c/1118

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/2024/GH/ 04

Dated: 02/01/2025

To,

Jt. CP (Licensing),
1st floor, Licensing unit, Police Station,
Defence Colony,
New Delhi-

Sub:Renewal of FSC in r/o M/s Hotel Taj Princess, located at 25 Block No.15A, W.E.A, Karol Bagh, Delhi-110005.

Sir,

This is reference to online application no. 202412141815 dated 16.12.2024, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **24.12.2024**, in presence of **Sh. Swagat Das (Manager)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Fire check door not provided.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on MHA Portal with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form MHA Portal are as under:

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/htt
p://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours faithfully

(Atul Garg)
DIRECTOR

Ph; 011-23414000

Copy to:-

1. MHA Portal ID-202412141815 dated 16.12.2024.