



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

C-51



No F6/DFS/MS/2025/WZ/GH/ 341

Dated: 15/05/2025

FIRE SAFETY CERTIFICATE

Certified that the M/s Hotel Tara Palace located at Prop. No.4606, Street No.13, Ansari Road, Daryaganj, Delhi-110002, building comprised of Basement + Stilt + ground + 04 upper floors but guest house is running at Ground + 03 upper floors, ground floor-04 guest rooms, 1st floor-07 guest rooms, 2nd floor-07 & 3rd floor-06 guest rooms, Total-24 guest rooms, has already been issued FSC by this department vide letter No. F.6/DFS/MS/GH/NDZ/2022/389 dated 17.08.2022. The premises was re-inspected by the officer concerned of this department on 05.05.2025 in the presence of Mr. Naveen (Manager) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class Residential, Sub Division A-1 for ground + 03 upper floor, (total-24 guest room only) with effect from 15/05/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010

Issued on 15/05/2025 at New Delhi by

(Atul Garg)
DIRECTOR

Ph; 011-23414000

Copy to:-

1. MCD Portal DI-2025041506460 dated 15.04.2025.
2. The Joint Commissioner of Police (Lic.) 1st floor, Licensing unit, Police Station, Defence Colony, New Delhi-

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management/occupier.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building	M/s Hotel Tara Palace located at Prop. No.4606, Street No.13, Ansari Road, Daryaganj, Delhi-110002.			
2. Type of Occupancy	Residential, Sub Division A-1			
3. Comprised of building	Basement + Stilt + UGF + 04 upper floors.			
4. Type of Case	Renewal (Ground + 03 upper floors, Total -24 guest rooms) Ground floor-04 guest rooms 1 st floor-07 guest rooms 2 nd floor-07 guest rooms 3 rd floor-06 guest rooms			
5. Details of Previous NOC	F.6/DFS/MS/GH/NDZ/2022/389 dated 17.08.2022.			
6. Fire Safety directives letter No	-NA-			
7. Date of inspection	05.05.2025			
8. Name of Inspecting Officer	Sh. Ajay Kumar Sharma (ADO Rohini)			
9. Name and designation of officers From the building side	Mr. Naveen (Manager)			
10. Year of Construction	2010 (Plan Approved)			
11. Applicant's letter No.	Online application No.2025041506460 dated 15.04.2025			
S. No	Minimum Standards on fire prevention and fire safety U/R 33	Requirement /Existing Fire Safety Measures	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	06m	06m	MR
	• Gate width	-NA-	-NA-	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01nos.	01nos.	MR
	• Basements	-NA-	-NA-	-NA-
	b. Width of staircases			
	• Upper Floor	1.25m	1.25m	MR
	• Basements	-NA-	-NA-	-NA-
	c. Protection of exits	As per clause 7.31 of UBBL 2016		
	• Fire check door	Required	Provided	MR
	• Pressurization	-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	01nos.	Provided	MR
	e. Width of Corridor	-NA-	-NA-	-NA-
	f. Door Size	1.0m	1.0m	MR
3.	Compartmentation			
	a) Fire check door	-NA-	-NA-	-NA-
	b) Sealing of electrical shafts	-NA-	-NA-	-NA-
	c) Fire Rating of shaft door	-NA-	-NA-	-NA-
	d) Water Curtain	-NA-	-NA-	-NA-
	e) Fire Dampers	-NA-	-NA-	-NA-
4.	Smoke Management System	As per clause 7.31 of UBBL 2016		
	a) Basements	-NA-	-NA-	-NA-
	b) Upper floors	12 a/c per hour	Natural ventilation	MR
5.	Fire Extinguishers			
	a) Total numbers	12nos.	Provided	MR
	b) Types	ABC/CO2	ABC/CO2	MR
	c) IS marking	ISI marked	Yes	MR

my

6.	First-Aid Hose Reels			
	a) Total numbers on each floor	01nos.	Provided	MR
	b) Length of hose reel hose	30mm	Provided	MR
	c) Nozzle diameter	5m	Provided	MR
7.	Automatic fire detection and alarming system			
	a) Type of detectors	Required	Provided	MR
	b) Location of Main Panel	Required	UG floor	MR
	c) Location of Repeater Panel	-NA-	-NA-	-NA-
	d) Alternate source of power	Required	Provided	MR
	e) Hooters' Location	Each floor	Provided	MR
8.	MOEFA			
9.	Public Address System			
10.	Automatic Sprinkler System			
	a) Basement	-NA-	-NA-	-NA-
	b) Ground & Upper Floors	-NA-	-NA-	-NA-
	c) Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants			
	a) Size of riser/down-comer	-NA-	100mm	-NA-
	b) Number of hydrants per floor	-NA-	01nos.	-NA-
	c) Hose Box	-NA-	01nos.	-NA-
12.	Yard Hydrants			
	a) Total number of hydrants	-NA-	-NA-	-NA-
	b) Hose Box	-NA-	-NA-	-NA-
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	-NA-	-NA-	-NA-
	➤ Head of Main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey Pump out put	-NA-	-NA-	-NA-
	➤ Jockey pump head	-NA-	-NA-	-NA-
	➤ Standby Pump out put	-NA-	-NA-	-NA-
	➤ Standby Pump Head	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	Terrace level			
	➤ Discharge of pump	450lpm	450lpm	MR
	➤ Head of the pump	30m	30m	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	-NA-	-NA-	-NA-
	➤ Draw-off connection	-NA-	-NA-	-NA-
	➤ Fire service inlet	-NA-	-NA-	-NA-
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	5,000ltr	Provided	MR
5.	Exit Signage.			
5.	Provision of Lifts.			
	a) Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	b) Pressurization of Lift lobby	-NA-	-NA-	-NA-

MJ	c) Communication In lift Car	Required	Provided	MR
M	d) Fireman's Grounding Switch	Required	Provided	MR
M	e) Lift Signage	Required	Provided	MR
M	17. Standby power supply	Required	Provided	MR
18.	Refuge Area.	Required	Provided	MR
	a) Total Area	-NA-	-NA-	-NA-
	b) Location	-NA-	-NA-	-NA-
19.	Fire Control Room	-NA-	-NA-	-NA-
	a) Detector System Panel	-NA-	-NA-	-NA-
	b) Flow Switch Panel	-NA-	-NA-	-NA-
	c) PA System Panel	-NA-	-NA-	-NA-
	d) Battery backup	-NA-	-NA-	-NA-
	e) Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risks, if any:	-NA-	Provided at D.G. Set	-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.
Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part-4, and removal of shortcomings issued vide letter no. 172 dated 16.04.2025, the FSC issued vide letter no. F.6/DFS/MS/GH/NDZ/2022/389 dated 17.08.2022, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

[Signature]
Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)

DO (CO)

[Signature]
7/5/25

[Signature]
S. J. R. (AD2)

[Signature]
28/05/25

C.F.O.

[Signature]

10/5/2025

[Signature]
Director

[Signature]
Ajay Kumar

FT letter to put up
for kind perusal &
Signature please.

[Signature]
Director
15/5/25

[Signature]
15/5/25

[Signature]
14/5/25