

clob

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/GH/NDZ/ 26

Dated:-15/01/2025

To,

The Manager,  
M/S Hotel The Rise,  
Shop no. A-110/1, Road no. 5,  
Gali no. 8, Mahipalpur, Delhi.

**Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Hotel The Rise, Shop no. A-110/1, Road no. 5, Gali no. 8, Mahipalpur, Delhi.**

Sir,

This has reference to on line ID No.2024121618064 dated 16.12.24, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 03/01/2025 in the presence of Sh. Manjeet Singh, Owner and following shortcomings were observed: -

1. Alternate staircase of 1.5 meter to the basement is not provided.
2. PA system is not provided.
3. Room at 4<sup>th</sup> floor is not allowed as per gazette notification 2019.

In view of above, the case is rejected and Fire Safety Certificate cannot be issued. Therefore, you are requested to rectify the shortcomings for further consideration in the matter.

Yours faithfully,

(Atul Chugh)  
DIRECTOR  
07123414000

Copy to:-

1. The Addl. Commissioner of Police (Lic.) First floor, PS Defence Colony New Delhi.