

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No. F.6/DFS/MS/GH/2025/SZ/ 19.

Dated: 10 / 01 / 2025

To

The Joint Commissioner of Police (Licensing)
1st Floor, Police Station Defence Colony,
New Delhi 110049

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Hotel TJS Grand, located at
16/7, WEA Karol Bagh, New Delhi-110005

Sir,

This has reference with **MCD Portal ID 2024122018229 dated 20/12/2024** on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 08/01/2025 in the presence of Mr. Balwan Singh to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

1. First Aid Hose Reel provided but found non- functional.
2. Automatic Sprinkler System found non- functional.
3. Fire fighting pump capacity 450 LPM provided but found non- functional.
4. Exit Signage found removed at some places.
5. Electrical Panel inside staircase is not allowed. The second staircase communicated for basement to ground, found closed.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE