

chog

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/NDZ/2025/ 49

Dated:- 29/01/2025

To

The Manager
M/s Hotel Vardhmaan Inn 1521 to 1527,
Part of GF,FF,SF,TF& above, Gali no-27,
SK Dass Road, Naiwala, Karol Bagh,
New Delhi.

Sub: Regarding issuance of FSC in r/o M/s Hotel Vardhmaan Inn 1521 to 1527, Part of GF,FF,SF,TF& above, Gali no-27, SK Dass Road, Naiwala, Karol Bagh, New Delhi.

Sir,

This has reference to online id no. 2025010800279 dated.09.01.2025, on the subject cited above. In this connection, it is to inform you that the site was inspected by the officer concerned of this department on 23/01/25 in the presence of Manager and following shortcomings were observed:-

1. CO detectors found non functional.
2. Pump found non functional.

Hence, the case is rejected and Fire Safety Certificate (FSC) cannot be renewed at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter

Yours faithfully,


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to :-

1. The Commissioner, MCD, Civic Centre, New Delhi.
2. The Addl. Commissioner of Police (Lic.) First floor, PS Defense Colony, New Delhi.