



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F.6/DFS/MS/2025/ GH/73

Dated: 11/02/2025

To,

Sh. Mehboob Ali,
House No. 3224, Street Phatak Teliyan,
Turakman Gate Delhi-110006

Sub:- Regarding issuance of Fire Safety Certificate in r/o Hotel White Place at Property No. 3034, Main Bazar, Turakman Gate Delhi-110006

Sir,

With reference to your application no. 2024061009151 dated 28.01.2025 on the subject cited above, it is informed that this department has already issued shortcomings vide letter no F.6/DFS/MS/GH/2025/SZ/20 dated 10.01.2025, and still not complied (Copy of the same is enclosed for your reference).

Encl: As above

Yours faithfully,

(Anil Garg)
Director

Copy to :-

1. The Joint Commissioner of Police (Licensing), 1st Floor, Police Station, Defence Colony, New Delhi.



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.G.DES-MS-GH/2025/SZ/ 20

Dated: 10/01/2025

To

The Joint Commissioner of Police (Lic.),
1st Floor, P.S. Defense Colony
New Delhi-110049

Sub: Inspection report in r/o M/s Hotel White Palace located at Prop. No. 3034, Main Bazar,
Turkman Gate, Delhi-110006

Sir,

This has reference to online application No. 2025010100018 dated 01/01/2025. In this connection, it is to inform you that the said premise was inspected by the officer concerned of this department on dated 06/01/2025 in the presence of Sh. Mehboob Ali (Owner) of the guest house, from fire safety point of view. During the inspection, the shortcomings observed are as below.

1. Portable fire extinguisher found empty/unrefilled and corroded.
2. First aid hose reel provided found non-functional.
3. Exit signage found removed at some location.
4. Overhead water storage tank exclusively for fire-fighting found tapped for domestic uses.

In view of the above, the application for renewal of fire safety certificate is rejected. The occupancy of the premises in the absence of requisite fire safety certificate/arrangements shall be at the risk and liability of the owner/occupier. The local/licensing authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL KARG)
DIRECTOR

T. No. 011-23414000

Copy to:-

1. Authorized Signatory M/s Hotel White Palace, Prop. No. 3034, Main Bazar, Turkman Gate, Delhi-110006