



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2025/School/ 38

Dated: 17/01/2025

To

The Principal,
Govt. Sarvodaya Bal Vidyalaya
C.C. Colony, Delhi-110007.

Sub: - Regarding renewal of fire safety certificate in r/o Govt. Sarvodaya Bal Vidyalaya (I.D No.1309001) located at C.C. Colony, Delhi-110007.

Sir,

Please refer to your letter no. SBV/CCC/2024/1343 dated: 19.12.2024 on the subject cited above. In this connection this is to inform you that the above mentioned site was inspected by the officer concerned of this department on 08.01.2025 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of 03 blocks, one block comprised of ground + 03 upper floors, 2nd block comprised of ground + first floor & 3rd block comprised of ground floor only. At the time of inspection Sh. D.C. Mehar (Vice-Principal) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. Hose reel hose is provided but not functional and damaged condition, some nozzle found missing.
2. Internal hydrant is provided but not functional and damaged condition, some nozzle found missing.
3. Terrace level fire pump is provided but not functional and damaged condition.
4. Terrace level fire water tank is provided but empty.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school is at your own risk & responsibility.

Yours faithfully

(Atul Garg)
Director
Ph:-011-23414000

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.

14/1