

C-122

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/GH/NDZ/ 2024/ 321

Dated:- 11/07/2024

To,

The Manager  
M/s Hridey Inn,  
T-119, 340, General Market,  
Main Bazar, New Delhi- 110055.

**Sub: Issuance of FSC (Fire Safety Certificate) in r/o ~~M/s~~ M/s Hridey Inn, T-119, 340, General Market, Main Bazar, New Delhi- 110055.**

Sir,

This has reference to your online id no. 2025062310477 dated 23/06/25, on the subject cited above. In this regard, it is to inform you that the site was visited by officer concerned of this department on dated 07/07/25 in presence of Mr. Vishal Manager and observed that shortcomings ( except point no.2) ,issued earlier vide letter no. F6/DFS/MS/GH/NDZ/200 dated 28/04/25 (copy enclosed), have not been complied so far.

In view of above, the case is rejected and FSC can't be issued till the compliance of all the shortcomings issued vide aforesaid letter.

Encl: As above.

Yours faithfully,

(Atul Garg)  
DIRECTOR  
Delhi Fire Service

Copy to :

1. The Addl. Commissioner of Police (Lic.) First floor, PS Defense Colony, New Delhi.

108 115 121

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/GH/NDZ/ 200

Dated: 28/04/2025

To,

The Manager  
M/S ~~M/s~~ Hriday Inn Guest House,  
T-119 340, General Market, Pahar Ganj,  
New Delhi.

**Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/s Hriday Inn Guest House at T-119 340, General Market, Pahar Ganj, New Delhi.**

Sir,

This has reference to Online id no. 2025032204306 dated 02.04.25, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 22/04/25 in the presence of Mr. Vishal and following shortcomings were observed: -

1. PA System non functional.
2. MOEFA found non functional.
3. Over head tank of 4000 against the requirement of 5,000.

Hence, Fire Safety Certificate (FSC) cannot be renewed at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,

(Anul Garg)  
DIRECTOR  
Delhi Fire Service

Copy to:

1. Addl. Commissioner of Police( lic), 1st floor, Defence Colony Police Station, New Delhi