



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

DAF+FT

75  
आज़ादी का  
अमृत महोत्सव

No. F6/DFS/MS/Hospital/NDZ/2025/1135

Dated 26/06/2025

To,

The Assistant Engineer(E),  
HE-3, HMED (East),  
GTB Hospital Complex,  
Shahdara, Delhi - 110095.

**Subject: - Regarding grant of Fire Safety Certificate in r/o Institute of Human Behavior & Allied Science, (IHBAS Hospital) located at Dilshad Garden, Delhi - 110095.**

Sir,

This has a reference to letter Outdoor Diary No. 2841 dated 18/06/2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 23/06/2025 in the presence of Mr. Avinash Kumar (J.E) and observed that the shortcomings intimated vide letter No. F6/DFS/MS/Hospital/NDZ/2024/502 dated 04/09/2024 (copy overleaf) has not been complied yet.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite fire safety requirements shall be at the risk and liability of the owner / occupier. The Licensing authority / Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

Enclose: As above.

(ATUL GARG)  
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to:-

1. The Director, IHBAS, Dilshad Garden, Delhi.
2. The Medical Superintendent, Nursing Homes, Directorate General of Health Services, Govt. of NCT of Delhi, 3<sup>rd</sup> floor, Delhi Govt. Dispensary Building, S-1, School Block, Shakarpur, Delhi - 110032.



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/Hospital/NDZ/2024/ 502

7/8  
आगामी  
अभिलेख  
कार्यालय  
लोडिंग  
स्वा  
01

Dated 04/09/2024

To,

The Executive Engineer,  
HMED (East), PWD,  
GTB Hospital Complex,  
Shahdara, Delhi - 110095.

**Subject: - Regarding grant of Fire Safety Certificate in r/o Institute of Human Behavior & Allied Science, (IHBAS Hospital) located at Dilshad Garden, Delhi - 110095.**

Sir,

This has a reference to your Outdoor Diary No. 4596 dated 26/07/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 27/08/2024 in the presence of Mr. C.L Meena (A.E/PWD) and observed that building comprised of ground plus two upper floors only.

**Following shortcomings were observed during time of inspection:**

1. First -Aid Hose reels provided but not functional.
2. Internal Hydrants provided but not functional.
3. Yard Hydrants provided but not functional.
4. All fire Pump provided but not functional.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to: -

1. The Medical Superintendent, Nursing Homes, Directorate General of Health Services, Govt. of NCT of Delhi, 3<sup>rd</sup> floor, Delhi Govt. Dispensary Building, S-1, School Block, Shakarpur, Delhi - 110032.