

C/28



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/2025/School/ 221

Dated: 15 / 04 / 2025

To,

The Headmistress,
 Ideal Public School at Gali No-2,
 B-Block, Saroop Vihar, Delhi-34.

Sub:- Regarding renewal of fire safety certificate in r/o Ideal Public School located at Gali No-2,
 B-Block, Saroop Vihar, Delhi-110034.

Sir,

Please refer to your letter No. 86/IPS/25 received in this department vide outdoor dairy no. 14661 dated 18.03.2025 on the subject cited above. In this connection this is to inform you the aforesaid building was inspected by the officers concerned of this department on 22.03.2025 in the presence of Smt. Urmila Rani (Principal) to verify the status of the shortcomings already issued by this department vide letter No.F6/DFS/MS/2024/School/529 dated 16.08.2024 and status is as under: -

S No.	Shortcomings	Status
1.	Hose reel hose is provided but found not functional and damaged condition.	Not Complied
2.	Terrace level fire pump capacity of 220lpm is provided but not functional & damaged condition.	Not Complied
3.	Terrace level fire water tank of capacity 2500ltrs is being used for domestic purposes. Fire water tank must be dedicated to firefighting purposes only.	Not Complied

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school building is at your own risk & responsibility.

Yours faithfully

(Signature)
 3/4/2025

(Virender Singh)
 Chief Fire Officer
 Delhi Fire Service

Copy to:-

1. The Deputy Director of Education, Zone-VII, District North Lucknow Road, Timarpur, Delhi - 110054.